

令和8年 6月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイクロストレーナ室(配水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	26.1	16.0	0.2	7.4							
2	曇	23.5	15.5	0.1	7.4							
3	雨	18.3	16.0	1.1	7.3							
4	曇	20.2	15.5	0.1	7.3							
5	曇	21.9	16.0	0.1	7.3							
6	曇	20.4	16.0	0.0	7.4							
7	曇	20.2	15.5	0.0	7.3							
8	曇	23.9	15.5	0.2	7.3	47.6	54.4	130	6.0	<0.03	<0.02	
9	雨	20.1	15.6	0.1	7.4							
10	曇	21.5	16.0	0.1	7.4							
11	晴	23.1	15.9	0.1	7.4							
12	晴	23.5	15.9	0.1	7.4							
13	曇	24.1	16.0	0.0	7.4							
14	曇	24.5	15.8	0.1	7.4							
15	曇	20.9	15.4	0.1	7.2							
16	晴	24.1	15.6	0.1	7.3							
17	晴	26.4	15.6	0.1	7.2							
18	雨	23.4	16.0	0.1	7.5							
19	晴	26.8	15.8	0.0	7.2							
20	雨	25.4	16.2	0.0	7.2							
21	雨	21.3	16.6	0.3	7.3							
22	晴	27.1	16.0	0.1	7.3	46.4	52.5	134	6.1	<0.03	<0.02	
23	曇	22.9	15.6	0.1	7.3							
24	曇	23.7	16.0	0.1	7.4							
25	雨	20.9	16.0	0.2	7.3							
26	曇	24.5	16.0	0.6	7.4							
27	雨	21.7	16.0	0.7	7.3							
28	雨	21.9	16.0	0.0	7.3							
29	曇	26.4	16.0	0.3	7.3							
30	晴	26.6	16.1	0.2	7.4							
平均		23.2	15.9	0.2	7.3	47.0	53.5	132	6.1	<0.03	<0.02	
最高		27.1	16.6	1.1	7.5	47.6	54.4	134	6.1	<0.03	<0.02	
最低		18.3	15.4	0.0	7.2	46.4	52.5	130	6.0	<0.03	<0.02	