

令和2年12月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	8.8	16.1	0.0	7.2							
2	曇	8.8	16.2	0.0	7.2							
3	曇	12.3	16.3	0.0	7.2							
4	曇	10.6	16.3	0.0	7.2							
5	雨	8.7	15.9	0.0	7.2							
6	晴	6.9	16.1	0.0	7.2							
7	晴	9.6	16.2	0.0	7.2							
8	晴	12.4	16.2	0.0	7.2							
9	曇	10.8	16.1	0.0	7.2							
10	曇	12.5	16.1	0.0	7.3	48.0	49.5	128	4.8	<0.03	<0.02	
11	晴	8.8	16.1	0.0	7.4							
12	雨	8.2	16.2	0.0	7.3							
13	晴	8.1	16.0	0.0	7.4							
14	晴	14.4	15.9	0.0	7.4							
15	晴	6.9	15.9	0.0	7.4							
16	晴	5.2	15.8	0.0	7.4							
17	晴	4.6	15.9	0.0	7.3	48.8	50.3	130	4.8	<0.03	<0.02	
18	晴	3.7	15.9	0.0	7.3							
19	晴	6.2	16.0	0.0	7.3							
20	晴	-0.7	15.7	0.0	7.3							
21	晴	3.1	15.8	0.0	7.3							
22	晴	2.4	15.8	0.0	7.3							
23	晴	1.9	15.8	0.0	7.3							
24	晴	10.8	16.1	0.0	7.3							
25	晴	10.5	16.0	0.1	7.4							
26	晴	2.3	15.8	0.0	7.3							
27	晴	5.0	16.0	0.0	7.3							
28	曇	7.5	16.1	0.0	7.3							
29	晴	3.6	15.9	0.0	7.3							
30	雨	11.8	16.1	0.7	7.3							
31	晴	0.2	15.8	0.0	7.3							
平均		7.3	16.0	0.0	7.3	48.4	49.9	129	4.8	<0.03	<0.02	
最高		14.4	16.3	0.7	7.4	48.8	50.3	130	4.8	<0.03	<0.02	
最低		-0.7	15.7	0.0	7.2	48.0	49.5	128	4.8	<0.03	<0.02	