

令和4年 7月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	32.4	16.4	0.1	7.4							
2	曇	28.7	16.3	0.0	7.3							
3	曇	28.0	16.1	0.0	7.3							
4	曇	28.2	16.7	0.2	7.4							
5	雨	25.5	16.3	0.1	7.4							
6	晴	28.2	16.6	0.0	7.4							
7	晴	29.4	16.4	0.1	7.3	47.1	51.7	123	5.2	<0.03	<0.02	
8	曇	27.1	16.8	0.2	7.3							
9	曇	27.5	16.2	0.0	7.3							
10	曇	25.6	16.1	0.0	7.3							
11	晴	31.5	16.5	0.0	7.4							
12	曇	29.0	16.4	0.0	7.4							
13	曇	26.4	16.3	0.0	7.4							
14	曇	28.3	16.6	0.0	7.4							
15	雨	25.6	16.8	0.1	7.4							
16	曇	25.5	16.1	0.1	7.4							
17	晴	24.7	16.0	0.0	7.2							
18	曇	26.7	16.1	0.0	7.2							
19	雨	26.0	16.4	0.8	7.3							
20	晴	28.7	16.6	0.0	7.3	47.3	53.9	135	5.3	<0.03	<0.02	
21	曇	29.4	16.4	0.0	7.3							
22	雨	26.6	16.3	0.0	7.3							
23	晴	29.2	16.3	0.0	7.4							
24	晴	30.2	16.3	0.0	7.4							
25	晴	32.0	17.0	0.0	7.5							
26	雨	26.6	17.4	1.0	7.4							
27	曇	29.2	16.5	0.0	7.4							
28	晴	30.2	17.1	0.0	7.5							
29	晴	31.5	16.5	0.0	7.4							
30	晴	30.8	16.5	0.0	7.4							
31	晴	31.4	16.5	0.0	7.4							
平均		28.4	16.5	0.1	7.4	47.2	52.8	129	5.2	<0.03	<0.02	
最高		32.4	17.4	1.0	7.5	47.3	53.9	135	5.3	<0.03	<0.02	
最低		24.7	16.0	0.0	7.2	47.1	51.7	123	5.2	<0.03	<0.02	