

令和4年11月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	曇	16.4	15.9	0.0	7.2							
2	晴	16.8	16.0	0.0	7.2							
3	晴	15.8	15.9	0.0	7.2							
4	晴	18.6	16.0	0.0	7.3							
5	晴	15.7	15.9	0.0	7.2							
6	晴	12.7	15.7	0.0	7.2							
7	晴	15.2	16.2	0.0	7.2							
8	晴	15.3	15.9	0.0	7.2							
9	晴	13.8	16.1	0.1	7.2	47.4	46.3	122	5.2	<0.03	<0.02	
10	晴	15.0	16.3	0.1	7.3							
11	晴	15.1	16.1	0.0	7.4							
12	晴	柿田川工業用水断水作業										
13	曇	15.9	15.8	0.0	7.4							
14	晴	16.8	16.0	0.0	7.4							
15	曇	12.7	16.0	0.0	7.4							
16	晴	14.0	16.0	0.0	7.4							
17	晴	9.9	16.0	0.0	7.2	46.3	49.1	124	5.2	<0.03	<0.02	
18	晴	12.8	16.1	0.0	7.4							
19	晴	10.8	16.0	0.0	7.4							
20	曇	15.5	15.9	0.0	7.4							
21	雨	14.7	15.9	0.0	7.3							
22	晴	14.1	15.9	0.0	7.3							
23	雨	13.7	15.8	0.0	7.2							
24	晴	12.5	15.9	0.0	7.2							
25	晴	14.5	15.9	0.0	7.2							
26	雨	12.2	15.7	0.1	7.2							
27	晴	12.1	15.8	0.0	7.1							
28	曇	12.9	16.2	0.0	7.2							
29	曇	16.0	16.4	0.0	7.2							
30	晴	21.2	16.4	0.0	7.2							
平均		14.6	16.0	0.0	7.3	46.9	47.7	123	5.2	<0.03	<0.02	
最高		21.2	16.4	0.1	7.4	47.4	49.1	124	5.2	<0.03	<0.02	
最低		9.9	15.7	0.0	7.1	46.3	46.3	122	5.2	<0.03	<0.02	