

令和5年 1月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	1.2	15.2	0.0	7.3							
2	晴	3.4	15.5	0.0	7.1							
3	晴	2.6	15.6	0.0	7.2							
4	晴	2.3	15.6	0.0	7.2							
5	晴	3.6	15.6	0.0	7.1							
6	晴	1.7	15.5	0.0	7.1							
7	晴	3.1	15.6	0.0	7.2							
8	晴	1.7	15.6	0.0	7.1							
9	晴	3.0	15.4	0.0	7.2							
10	晴	9.2	15.6	0.0	7.2							
11	晴	2.7	15.8	0.1	7.2	46.4	41.1	121	5.0	<0.03	<0.02	
12	晴	3.3	15.7	0.0	7.3							
13	晴	3.5	15.8	0.0	7.3							
14	雨	12.8	15.9	0.0	7.3							
15	曇	12.7	15.9	0.0	7.3							
16	曇	10.1	15.7	0.0	7.2							
17	曇	5.3	15.7	0.0	7.3							
18	曇	7.6	15.7	0.0	7.3							
19	晴	6.1	15.6	0.0	7.4							
20	晴	5.4	15.6	0.0	7.3							
21	晴	4.2	15.5	0.0	7.3							
22	晴	4.3	15.5	0.0	7.3							
23	雨	6.3	15.6	0.0	7.2							
24	曇	7.3	15.7	0.1	7.2	46.5	45.0	118	5.0	<0.03	<0.02	
25	晴	1.0	15.4	0.0	7.2							
26	晴	0.0	15.5	0.0	7.2							
27	晴	3.7	15.5	0.0	7.2							
28	晴	0.3	15.3	0.0	7.3							
29	晴	1.4	15.4	0.0	7.3							
30	晴	1.9	15.7	0.0	7.1							
31	晴	3.2	15.6	0.1	7.2							
平均		4.4	15.6	0.0	7.2	46.5	43.1	120	5.0	<0.03	<0.02	
最高		12.8	15.9	0.1	7.4	46.5	45.0	121	5.0	<0.03	<0.02	
最低		0.0	15.2	0.0	7.1	46.4	41.1	118	5.0	<0.03	<0.02	