

令和5年 9月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残留 物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	28.4	16.4	0.1	7.2							
2	晴	29.1	16.7	0.0	7.2							
3	晴	29.8	16.4	0.0	7.2							
4	曇	28.2	16.9	0.1	7.2							
5	晴	28.1	16.8	0.4	7.1	51.7	49.1	121	5.1	<0.03	<0.02	
6	曇	28.8	16.8	0.1	7.1							
7	曇	26.1	16.2	0.1	7.2							
8	曇	22.1	16.3	0.1	7.2							
9	曇	26.5	16.3	0.0	7.2							
10	曇	27.4	16.4	0.0	7.2							
11	晴	28.2	16.6	0.1	7.2							
12	晴	28.3	16.8	0.0	7.2							
13	晴	26.2	16.5	0.1	7.3							
14	晴	27.4	16.6	0.3	7.2							
15	晴	30.5	17.0	0.1	7.2							
16	曇	28.7	16.4	0.0	7.1							
17	晴	29.2	16.6	0.0	7.2							
18	晴	29.0	16.5	0.0	7.3							
19	晴	29.2	16.5	0.1	7.3	52.0	51.4	126	5.2	<0.03	<0.02	
20	晴	29.9	16.6	0.0	7.2							
21	曇	27.1	16.5	0.2	7.2							
22	曇	25.9	16.8	0.1	7.2							
23	雨	23.8	16.1	0.0	7.1							
24	晴	22.7	16.4	0.1	7.2							
25	晴	24.4	16.4	0.0	7.3							
26	晴	24.8	16.4	0.0	7.2							
27	晴	24.3	16.8	0.0	7.2							
28	晴	27.9	16.6	0.0	7.2							
29	晴	28.4	16.4	0.0	7.3							
30	曇	26.3	16.4	0.0	7.2							
31												
平均		27.2	16.5	0.1	7.2	51.9	50.3	124	5.2	<0.03	<0.02	
最高		30.5	17.0	0.4	7.3	52.0	51.4	126	5.2	<0.03	<0.02	
最低		22.1	16.1	0.0	7.1	51.7	49.1	121	5.1	<0.03	<0.02	