

令和5年10月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残留 物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	28.1	16.9	0.0	7.2							
2	晴	25.5	16.9	0.0	7.2							
3	晴	23.2	16.3	0.1	7.2	53.4	47.6	118	5.1	<0.03	<0.02	
4	雨	20.1	16.6	0.1	7.2							
5	曇	22.1	16.5	0.4	7.2							
6	晴	18.7	16.5	0.0	7.2							
7	晴	17.6	16.0	0.0	7.3							
8	曇	20.0	16.0	0.0	7.2							
9	雨	17.9	16.1	0.0	7.3							
10	曇	28.4	16.1	2.5	7.3							
11	晴	20.2	16.6	0.0	7.2							
12	晴	18.8	16.3	0.1	7.2							
13	晴	18.1	16.3	0.0	7.2							
14	晴	15.4	16.1	0.0	7.3							
15	雨	16.3	16.2	1.0	7.2							
16	晴	18.1	16.1	0.1	7.2							
17	晴	17.0	16.1	0.1	7.2	50.2	48.2	120	5.1	<0.03	<0.02	
18	晴	18.6	16.2	0.0	7.3							
19	晴	19.5	16.2	0.0	7.3							
20	晴	22.0	16.4	0.2	7.3							
21	晴	18.7	16.0	0.0	7.3							
22	晴	15.2	16.0	0.0	7.3							
23	晴	15.6	16.3	0.1	7.3							
24	晴	16.0	16.4	0.0	7.3							
25	晴	14.5	16.4	0.1	7.3							
26	晴	16.1	16.1	0.0	7.3							
27	晴	16.1	16.3	0.0	7.3							
28	晴	16.0	16.0	0.0	7.3							
29	曇	14.7	16.0	0.0	7.3							
30	晴	12.9	16.0	0.1	7.3							
31	曇	15.9	16.0	0.1	7.3							
平均		18.6	16.3	0.2	7.3	51.8	47.9	119	5.1	<0.03	<0.02	
最高		28.4	16.9	2.5	7.3	53.4	48.2	120	5.1	<0.03	<0.02	
最低		12.9	16.0	0.0	7.2	50.2	47.6	118	5.1	<0.03	<0.02	