

令和7年 8月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	32.7	16.0	0.1	7.3							
2	晴	33.0	15.7	0.1	7.3							
3	晴	33.0	15.6	0.0	7.3							
4	晴	31.2	15.9	0.1	7.3	50.2	54.3	130	5.7	<0.03	<0.02	
5	曇	30.0	16.1	0.2	7.3							
6	晴	33.0	16.0	0.3	7.3							
7	晴	30.9	15.9	0.1	7.3							
8	晴	30.2	16.0	0.1	7.3							
9	晴	30.9	15.7	0.0	7.3							
10	雨	26.8	16.6	0.2	7.3							
11	曇	27.5	16.3	0.0	7.4							
12	曇	28.1	15.9	0.1	7.4							
13	曇	29.8	15.9	0.2	7.4							
14	曇	25.4	15.7	0.2	7.3							
15	晴	28.6	15.8	0.1	7.5							
16	雨	25.6	16.3	0.2	7.5							
17	曇	27.1	16.3	0.0	7.5							
18	晴	30.0	15.8	0.3	7.5	49.8	53.4	126	5.7	<0.03	<0.02	
19	晴	28.9	15.8	0.1	7.4							
20	晴	29.2	15.9	0.1	7.4							
21	晴	30.5	16.0	0.1	7.4							
22	晴	29.8	15.9	0.1	7.3							
23	晴	30.2	15.8	0.0	7.3							
24	晴	30.0	15.9	0.0	7.3							
25	晴	31.4	16.0	0.1	7.4							
26	晴	30.4	16.0	0.1	7.3							
27	晴	29.5	16.0	0.1	7.3							
28	曇	29.8	15.9	0.1	7.3							
29	晴	29.4	16.0	0.1	7.4							
30	晴	30.5	16.2	0.0	7.4							
31	晴	30.2	15.7	0.1	7.2							
平 均		29.8	16.0	0.1	7.3	50.0	53.9	128	5.7	<0.03	<0.02	
最 高		33.0	16.6	0.3	7.5	50.2	54.3	130	5.7	<0.03	<0.02	
最 低		25.4	15.6	0.0	7.2	49.8	53.4	126	5.7	<0.03	<0.02	