

令和8年 2月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイクロストレナ室(配水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	0.4	15.2	0.0	7.2							
2	晴	2.9	15.0	0.0	7.1	47.7	51.7	119	5.6	<0.03	<0.02	
3	晴	1.4	15.0	0.0	7.1							
4	晴	3.1	15.1	0.0	7.2							
5	晴	2.4	15.1	0.0	7.2							
6	晴	4.3	15.4	0.0	7.2							
7	雨	5.9	15.1	0.0	7.2							
8	晴	6.0	15.0	0.0	7.2							
9	晴	-1.4	15.0	0.0	7.2							
10	晴	2.1	15.1	0.0	7.2							
11	雨	8.9	15.0	0.6	7.1							
12	曇	8.3	15.2	0.1	7.2							
13	曇	3.4	15.1	0.0	7.2							
14	晴	4.4	15.6	0.0	7.0							
15	晴	10.7	15.2	0.0	7.1							
16	晴	10.2	15.4	0.0	7.2	48.0	52.0	124	5.7	<0.03	<0.02	
17	曇	5.1	15.2	0.1	7.1							
18	晴	5.0	15.1	0.1	7.2							
19	晴	4.3	15.3	0.0	7.1							
20	晴	5.9	15.1	0.1	7.2							
21	晴	5.4	15.1	0.0	7.1							
22	晴	5.9	15.3	0.0	7.2							
23	晴	17.1	15.4	0.0	7.1							
24	晴	10.9	15.3	0.1	7.3							
25	雨	15.0	15.4	0.3	7.2							
26	晴	12.8	15.4	0.1	7.2							
27	晴	10.4	15.4	0.0	7.3							
28	晴	12.4	15.3	0.0	7.3							
平均		6.5	15.2	0.1	7.2	47.9	51.9	122	5.7	<0.03	<0.02	
最高		17.1	15.6	0.6	7.3	48.0	52.0	124	5.7	<0.03	<0.02	
最低		-1.4	15.0	0.0	7.0	47.7	51.7	119	5.6	<0.03	<0.02	