

令和8年 3月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイクロストレーナ室(配水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	10.1	15.4	0.0	7.3							
2	晴	13.6	15.3	0.1	7.3	47.3	51.9	130	5.7	<0.03	<0.02	
3	雨	9.1	15.0	0.1	7.2							
4	晴	11.2	15.4	0.0	7.3							
5	晴	8.4	15.2	0.1	7.2							
6	曇	10.0	15.2	0.0	7.3							
7	晴	12.8	15.7	0.0	7.3							
8	晴	7.1	15.3	0.0	7.3							
9	晴	7.1	15.3	0.0	7.3							
10	晴	9.3	15.4	0.1	7.3							
11	曇	9.8	15.2	0.1	7.3							
12	晴	8.2	15.2	0.0	7.3							
13	曇	6.2	15.2	1.4	7.3							
14	晴	10.8	15.1	0.0	7.3							
15	曇	8.5	15.1	0.0	7.3							
16	曇	10.0	15.4	0.1	7.3	47.8	51.9	122	5.8	<0.03	<0.02	
17	曇	11.1	15.4	0.1	7.3							
18	晴	10.3	15.4	0.0	7.3							
19	雨	13.2	15.4	0.1	7.3							
20	晴	14.3	15.4	0.0	7.4							
21	晴	10.4	15.2	0.0	7.3							
22	晴	9.1	15.2	0.0	7.3							
23	雨	11.4	15.2	0.1	7.3							
24	晴	12.1	15.3	0.0	7.2							
25	雨	12.6	15.2	0.0	7.2							
26	曇	12.4	15.5	0.0	7.2							
27	晴	13.6	15.6	0.1	7.2							
28	晴	13.1	15.4	0.0	7.2							
29	晴	14.7	15.8	0.1	7.1							
30	曇	14.9	15.5	0.1	7.2							
31	雨	15.3	15.7	0.1	7.2							
平均		11.0	15.3	0.1	7.3	47.6	51.9	126	5.8	<0.03	<0.02	
最高		15.3	15.8	1.4	7.4	47.8	51.9	130	5.8	<0.03	<0.02	
最低		6.2	15.0	0.0	7.1	47.3	51.9	122	5.7	<0.03	<0.02	