

令和8年 4月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイクロストレーナ室(配水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	18.3	15.8	0.2	7.2							
2	曇	12.2	15.5	0.2	7.2							
3	晴	14.2	15.7	0.1	7.3							
4	曇	13.4	15.3	0.0	7.2							
5	晴	19.6	15.7	0.0	7.3							
6	晴	19.3	15.7	0.1	7.2	48.9	53.2	129	5.9	<0.03	<0.02	
7	曇	17.7	15.6	0.0	7.2							
8	晴	13.0	15.6	0.1	7.3							
9	晴	14.9	15.5	0.1	7.3							
10	雨	15.9	15.7	0.1	7.1							
11	晴	22.3	15.6	0.0	7.3							
12	晴	19.4	15.4	0.0	7.3							
13	曇	20.8	15.5	0.0	7.3							
14	晴	21.9	15.8	0.0	7.2							
15	曇	19.9	15.5	0.4	7.1							
16	晴	19.0	15.7	0.0	7.2							
17	晴	15.8	15.6	0.0	7.2							
18	曇	16.9	15.4	0.1	7.3							
19	晴	19.2	15.6	0.0	7.2							
20	晴	20.1	15.8	0.0	7.2	47.7	52.5	129	5.8	<0.03	<0.02	
21	晴	19.2	15.6	0.0	7.2							
22	晴	19.9	15.5	0.0	7.2							
23	曇	18.4	15.3	0.0	7.2							
24	曇	17.1	15.6	0.0	7.1							
25	曇	17.2	15.4	0.0	7.2							
26	晴	18.8	15.4	0.1	7.2							
27	曇	16.0	15.6	0.1	7.2							
28	晴	19.2	15.8	0.1	7.2							
29	晴	22.1	16.0	0.1	7.3							
30	曇	15.3	15.5	0.1	7.3							
平均		17.9	15.6	0.1	7.2	48.3	52.9	129	5.9	<0.03	<0.02	
最高		22.3	16.0	0.4	7.3	48.9	53.2	129	5.9	<0.03	<0.02	
最低		12.2	15.3	0.0	7.1	47.7	52.5	129	5.8	<0.03	<0.02	