

令和4年1月分

東駿河湾工業用水道 岳南水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井(原水))									備考 (日最大濁度)
			水温 °C	濁度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガ ン mg/l	
1	晴	2.0	6.8	5.0	7.76							5
2	曇	2.0	6.0	2.0	7.81							4
3	晴	3.0	5.9	2.2	7.76							3
4	晴	5.6	6.5	2.2	7.77							3
5	晴	5.5	6.5	2.1	7.77							3
6	曇	3.5	6.4	2.0	7.80							14
7	晴	2.5	6.0	2.6	7.74							20
8	晴	3.0	6.5	5.4	7.86							17
9	晴	4.8	6.5	5.9	7.73							27
10	晴	7.0	7.1	5.2	7.82							14
11	曇	8.0	7.9	3.0	7.80	58.5	72.1	146	9.9	0.44	0.03	23
12	晴	5.0	7.9	9.2	7.80							22
13	晴	3.0	7.5	6.4	7.80							17
14	晴	2.3	6.3	6.2	7.73							18
15	晴	4.5	6.8	3.6	7.89							16
16	曇	4.0	4.9	5.9	7.80							16
17	晴	7.0	6.9	5.9	7.85							18
18	晴	5.0	7.0	4.0	7.88	56.6	69.0	136	10.1	0.31	0.02	34
19	曇	2.9	6.9	6.7	7.86							61
20	晴	1.0	6.7	5.3	7.78							22
21	晴	3.0	6.7	9.0	7.79							26
22	晴	2.5	5.9	8.2	7.79							21
23	晴	3.0	6.3	6.1	7.89							30
24	曇	7.5	6.7	4.3	7.81							12
25	晴	2.0	7.8	4.5	7.82							14
26	晴	6.7	6.6	7.8	7.79							20
27	晴	5.2	8.7	6.3	7.81							20
28	曇	6.2	8.7	6.2	7.90							16
29	晴	5.0	7.9	5.5	7.85							23
30	曇	4.8	7.8	4.4	7.93							21
31	晴	6.0	7.8	5.3	7.92							24
平均		4.3	6.9	5.1	7.82	57.6	70.6	141	10.0	0.38	0.02	
最高		8.0	8.7	9.2	7.93	58.5	72.1	146	10.1	0.44	0.03	
最低		1.0	4.9	2.0	7.73	56.6	69.0	136	9.9	0.31	0.02	

令和4年1月分

東駿河湾工業用水道 水質試験結果報告書 (厚原浄水場)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.0	7.7	1.1	7.55							
2	曇	2.0	7.9	1.2	7.64							
3	晴	3.0	7.2	1.1	7.65							
4	晴	5.6	6.9	0.9	7.66							
5	晴	5.5	7.2	1.1	7.66							
6	曇	3.5	7.0	1.3	7.58							
7	晴	2.5	6.5	1.4	7.53							
8	晴	3.0	6.4	3.1	7.49							
9	晴	4.8	7.2	3.0	7.56							
10	晴	7.0	7.6	2.5	7.48							
11	曇	8.0	7.5	1.5	7.51	53.9	73.0	142	10.3	0.03	<0.02	
12	晴	5.0	8.3	1.7	7.51							
13	晴	3.0	7.5	2.0	7.37							
14	晴	2.3	6.2	2.1	7.58							
15	晴	4.5	6.1	2.5	7.43							
16	曇	4.0	6.6	1.6	7.47							
17	晴	7.0	7.0	2.1	7.49							
18	晴	5.0	7.0	1.6	7.50	51.6	71.8	131	10.5	0.06	<0.02	
19	曇	2.9	7.4	1.7	7.48							
20	晴	1.0	6.5	1.8	7.43							
21	晴	3.0	6.7	1.1	7.49							
22	晴	2.5	5.9	2.1	7.48							
23	晴	3.0	6.0	1.7	7.37							
24	曇	7.5	6.7	1.8	7.43							
25	晴	2.0	7.1	1.9	7.59							
26	晴	6.7	7.9	1.0	7.48							
27	晴	5.2	8.0	1.8	7.47							
28	曇	6.2	8.9	1.3	7.53							
29	晴	5.0	8.6	1.8	7.54							
30	曇	4.8	8.3	2.0	7.56							
31	晴	6.0	8.0	1.4	7.44							
平均		4.3	7.2	1.7	7.51	52.8	72.4	137	10.4	0.05	<0.02	
最高		8.0	8.9	3.1	7.66	53.9	73.0	142	10.5	0.06	<0.02	
最低		1.0	5.9	0.9	7.37	51.6	71.8	131	10.3	0.03	<0.02	