

令和4年2月分

東駿河湾工業用水道 岳南水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井(原水))									備考 (日最大濁度)
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	4.9	7.8	3.6	7.90	58.8	71.9	146	9.6	0.38	0.02	
2	晴	6.0	7.4	6.7	7.79							
3	曇	3.0	7.3	6.6	7.81							
4	曇	5.2	7.5	5.9	7.84							
5	晴	6.1	7.4	5.5	7.77							
6	晴	4.0	6.9	7.3	7.73							
7	晴	3.0	6.9	5.5	7.80							
8	曇	4.0	6.9	6.6	7.80							
9	晴	4.0	7.9	4.3	7.87							
10	雨	3.2	7.8	4.4	7.82							
11	晴	9.0	7.2	4.1	7.79							
12	晴	6.0	6.3	3.7	7.74							
13	曇	5.0	8.0	11.2	7.82							
14	曇	5.0	7.0	4.7	7.74							
15	曇	9.0	8.8	4.8	7.75	55.3	75.2	142	12.7	0.32	0.02	
16	晴	9.0	8.9	4.1	7.86							
17	晴	5.0	9.6	4.0	7.80							
18	晴	10.0	8.6	4.8	7.83							
19	曇	5.8	7.1	4.6	7.78							
20	曇	9.0	7.9	4.2	7.72							
21	晴	4.0	9.3	6.9	7.83							
22	晴	3.6	8.0	4.7	7.77							
23	晴	3.5	7.8	3.8	7.80							
24	晴	8.0	8.7	4.1	7.82							
25	晴	3.0	7.3	4.8	7.77							
26	晴	7.2	7.6	5.2	7.74							
27	晴	9.0	7.7	7.4	7.79							
28	晴	8.0	9.0	4.3	7.78							
平均		5.8	7.8	5.3	7.80	57.1	73.6	144	11.2	0.35	0.02	
最高		10.0	9.6	11.2	7.90	58.8	75.2	146	12.7	0.38	0.02	
最低		3.0	6.3	3.6	7.72	55.3	71.9	142	9.6	0.32	0.02	

令和4年2月分

東駿河湾工業用水道 水質試験結果報告書 (厚原浄水場)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池 (浄水) )									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	4.9	7.8	1.1	7.58	53.1	69.9	140	9.5	0.07	<0.02	
2	晴	6.0	7.0	1.9	7.50							
3	曇	3.0	7.0	1.4	7.45							
4	曇	5.2	7.2	1.4	7.44							
5	晴	6.1	8.0	1.7	7.58							
6	晴	4.0	7.7	1.8	7.50							
7	晴	3.0	7.2	1.5	7.59							
8	曇	4.0	7.4	1.2	7.58							
9	晴	4.0	7.7	1.6	7.45							
10	雨	3.2	7.5	1.5	7.43							
11	晴	9.0	8.6	1.5	7.50							
12	晴	6.0	6.8	1.5	7.49							
13	曇	5.0	7.8	1.3	7.46							
14	曇	5.0	8.0	1.5	7.55							
15	曇	9.0	8.1	1.3	7.48	49.2	79.1	139	12.8	0.07	<0.02	
16	晴	9.0	8.5	1.3	7.53							
17	晴	5.0	8.8	1.8	7.55							
18	晴	10.0	8.5	1.5	7.53							
19	曇	5.8	7.0	3.0	7.51							
20	曇	9.0	8.3	1.4	7.62							
21	晴	4.0	8.6	1.8	7.51							
22	晴	3.6	8.0	1.7	7.65							
23	晴	3.5	7.6	1.6	7.51							
24	晴	8.0	8.3	1.1	7.54							
25	晴	3.0	7.9	1.6	7.54							
26	晴	7.2	8.1	2.3	7.68							
27	晴	9.0	8.6	2.0	7.48							
28	晴	8.0	8.8	2.5	7.61							
29												
30												
31												
平均		5.8	7.9	1.6	7.53	51.2	74.5	140	11.2	0.07	<0.02	
最高		10.0	8.8	3.0	7.68	53.1	79.1	140	12.8	0.07	<0.02	
最低		3.0	6.8	1.1	7.43	49.2	69.9	139	9.5	0.07	<0.02	