

令和 2年12月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	8.5	10.8	18.2	7.81							
2	晴	9.0	11.0	23.4	7.82							
3	曇	7.5	11.2	22.8	7.80							
4	曇	7.5	11.6	10.9	7.84							
5	雨	8.0	10.8	19.1	7.85							
6	晴	5.5	11.0	14.1	7.81							
7	晴	6.5	10.8	4.8	7.77							
8	晴	6.5	11.0	9.6	7.73							
9	曇	9.5	11.8	22.1	7.74							
10	晴	7.0	11.0	16.5	7.78	55.0	70.0	159	9.4	1.22	0.04	
11	晴	6.0	11.0	12.7	7.81							
12	曇	9.0	11.2	13.0	7.75							
13	晴	6.5	-	-	-							定期断水
14	晴	11.5	11.4	10.4	7.74							
15	晴	3.0	10.0	8.8	7.79							
16	晴	-2.0	8.3	16.8	7.87							
17	晴	-2.0	7.5	7.1	7.71	56.0	70.0	139	9.8	0.61	0.02	
18	晴	-1.5	7.2	10.5	7.80							
19	晴	1.0	7.4	8.3	7.73							
20	晴	-1.5	7.6	4.1	7.77							
21	晴	0.5	6.8	3.6	7.79							
22	晴	1.0	6.8	3.5	7.74							
23	晴	2.5	7.1	11.1	7.79							
24	晴	0.0	7.4	4.3	7.80							
25	晴	3.0	7.6	4.7	7.78							
26	晴	-1.0	7.9	13.3	7.73							
27	晴	3.5	7.7	4.0	7.76							
28	雨	6.0	8.0	3.5	7.81							
29	晴	4.5	8.9	4.2	7.76							
30	雨	9.5	9.0	3.5	7.80							
31	晴	0.0	8.3	4.8	7.84							
平均		4.4	9.3	10.5	7.78	55.5	70.0	149	9.6	0.92	0.03	
最高		11.5	11.8	23.4	7.87	56.0	70.0	159	9.8	1.22	0.04	
最低		-2.0	6.8	3.5	7.71	55.0	70.0	139	9.4	0.61	0.02	

令和 2年12月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	8.5	11.1	0.8	7.62							
2	晴	9.0	11.2	2.6	7.62							
3	曇	7.5	11.5	1.0	7.58							
4	曇	7.5	12.1	1.0	7.58							
5	雨	8.0	11.7	1.0	7.62							
6	晴	5.5	11.4	1.1	7.56							
7	晴	6.5	11.4	0.8	7.56							
8	晴	6.5	11.4	0.8	7.53							
9	曇	9.5	11.8	1.1	7.58							
10	晴	7.0	11.8	1.0	7.55	51.0	71.0	130	9.5	0.05	<0.02	
11	晴	6.0	11.4	1.2	7.56							
12	曇	9.0	11.4	1.0	7.53							
13	晴	6.5	-	-	-							定期断水
14	晴	11.5	11.5	0.8	7.55							
15	晴	3.0	10.6	1.0	7.60							
16	晴	-2.0	8.9	1.1	7.54							
17	晴	-2.0	7.8	1.0	7.57	52.0	71.0	127	9.6	0.06	<0.02	
18	晴	-1.5	7.7	1.2	7.58							
19	晴	1.0	7.3	1.3	7.55							
20	晴	-1.5	7.5	1.0	7.57							
21	晴	0.5	7.0	1.4	7.54							
22	晴	1.0	6.9	1.1	7.59							
23	晴	2.5	7.1	1.3	7.58							
24	晴	0.0	7.2	1.3	7.63							
25	晴	3.0	7.4	1.2	7.54							
26	晴	-1.0	8.0	1.3	7.52							
27	晴	3.5	7.7	1.0	7.63							
28	雨	6.0	7.8	1.2	7.61							
29	晴	4.5	8.5	1.2	7.65							
30	雨	9.5	8.9	1.1	7.60							
31	晴	0.0	8.1	1.0	7.58							
平均		4.4	9.5	1.1	7.58	51.5	71.0	129	9.6	0.06	<0.02	
最高		11.5	12.1	2.6	7.65	52.0	71.0	130	9.6	0.06	<0.02	
最低		-2.0	6.9	0.8	7.52	51.0	71.0	127	9.5	0.05	<0.02	