

令和 3年 1月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	0.0	7.1	3.1	7.79							
2	晴	-2.0	6.9	2.7	7.83							
3	晴	-1.0	7.0	2.1	7.81							
4	晴	2.5	7.1	1.8	7.85							
5	曇	1.5	7.7	3.1	7.82							
6	曇	4.5	7.5	7.4	7.79							
7	曇	4.0	7.5	14.8	7.82	56.0	70.0	148	8.3	0.78	0.03	
8	晴	-2.5	7.0	15.8	7.81							
9	晴	-4.5	5.9	7.4	7.81							
10	晴	-4.0	5.0	5.2	7.78							
11	晴	-1.5	5.7	3.2	7.79							
12	晴	1.5	5.5	3.3	7.73							
13	晴	0.5	5.8	3.6	7.71							
14	晴	2.5	7.5	11.6	7.74							
15	晴	3.5	7.6	7.6	7.75							
16	晴	3.5	7.3	7.7	7.77							
17	曇	7.0	8.4	4.3	7.78							
18	曇	6.0	8.2	4.1	7.80							
19	晴	1.0	7.8	3.5	7.73	56.0	71.0	133	10.7	0.29	<0.02	
20	晴	2.5	7.6	5.3	7.75							
21	晴	3.0	6.9	4.1	7.73							
22	晴	3.5	7.0	4.3	7.76							
23	曇	10.0	8.3	4.6	7.80							
24	曇	7.0	8.3	5.8	7.72							
25	晴	4.5	8.4	9.0	7.71							
26	晴	4.5	9.6	9.0	7.68							
27	雨	10.5	9.5	5.6	7.74							
28	曇	7.0	10.0	36.4	7.75							
29	晴	5.0	8.0	15.0	7.75							
30	晴	-2.5	7.9	9.4	7.73							
31	晴	-1.0	7.0	4.9	7.75							
平均		2.5	7.5	7.3	7.77	56.0	70.5	141	9.5	0.54	0.03	
最高		10.5	10.0	36.4	7.85	56.0	71.0	148	10.7	0.78	0.03	
最低		-4.5	5.0	1.8	7.68	56.0	70.0	133	8.3	0.29	0.03	

令和 3年 1月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	0.0	7.3	1.3	7.60							
2	晴	-2.0	6.8	1.1	7.59							
3	晴	-1.0	6.8	0.9	7.63							
4	晴	2.5	7.0	0.8	7.67							
5	曇	1.5	7.2	0.9	7.62							
6	曇	4.5	7.4	1.0	7.63							
7	曇	4.0	7.8	0.8	7.63	52.0	68.0	131	9.2	0.06	<0.02	
8	晴	-2.5	7.7	1.3	7.60							
9	晴	-4.5	6.1	1.5	7.58							
10	晴	-4.0	5.2	1.0	7.52							
11	晴	-1.5	5.5	1.0	7.51							
12	晴	1.5	5.4	1.2	7.60							
13	晴	0.5	6.1	0.9	7.51							
14	晴	2.5	6.9	0.8	7.38							
15	晴	3.5	7.5	0.9	7.31							
16	晴	3.5	7.9	1.2	7.52							
17	曇	7.0	8.3	1.2	7.53							
18	曇	6.0	8.3	1.0	7.54							
19	晴	1.0	8.1	1.0	7.57	51.0	70.0	122	10.4	0.06	<0.02	
20	晴	2.5	7.7	1.2	7.54							
21	晴	3.0	7.0	1.2	7.58							
22	晴	3.5	7.0	1.3	7.57							
23	曇	10.0	8.1	1.2	7.55							
24	曇	7.0	8.6	1.1	7.60							
25	晴	4.5	8.6	1.5	7.46							
26	晴	4.5	9.6	1.5	7.42							
27	雨	10.5	9.4	1.0	7.46							
28	曇	7.0	10.2	1.7	7.44							
29	晴	5.0	8.8	1.4	7.44							
30	晴	-2.5	8.0	0.9	7.47							
31	晴	-1.0	6.8	1.4	7.49							
平均		2.5	7.5	1.1	7.53	51.5	69.0	127	9.8	0.06	<0.02	
最高		10.5	10.2	1.7	7.67	52.0	70.0	131	10.4	0.06	<0.02	
最低		-4.5	5.2	0.8	7.31	51.0	68.0	122	9.2	0.06	<0.02	