

令和4年12月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	13.0	14.4	43.7	7.66							
2	曇	10.0	12.4	19.5	7.82							
3	曇	7.0	11.8	10.6	7.76							
4	晴	6.5	11.2	5.8	7.45							
5	曇	10.5	11.7	3.8	7.67							
6	曇	9.0	11.9	4.7	7.66							
7	晴	4.0	11.2	4.2	7.33	56.0	72.9	147	7.1	0.32	<0.02	
8	晴	3.5	10.4	6.7	7.48							
9	晴	7.0	10.3	3.7	7.47							
10	晴	6.0	9.8	12.0	7.48							
11	曇	6.5	9.0	9.7	7.41							
12	晴	6.0	9.5	14.1	7.32							
13	雨	7.0	10.1	3.5	7.70							
14	晴	11.0	10.5	6.5	7.80							
15	晴	3.0	9.4	3.2	7.53							
16	晴	2.0	8.8	5.4	7.42							
17	曇	4.0	9.0	3.8	7.64							
18	晴	5.0	8.8	2.8	7.50							
19	晴	-1.5	7.0	2.9	7.52							
20	晴	-1.0	7.3	11.4	7.47							
21	晴	1.0	7.2	9.1	7.45	58.5	78.2	176	7.5	0.71	0.02	
22	雨	8.0	8.2	3.3	7.79							
23	晴	3.0	7.3	26.9	7.37							
24	晴	3.0	6.4	11.4	7.56							
25	晴	1.0	7.0	4.4	7.55							
26	晴	1.5	7.0	4.2	7.47							
27	晴	6.0	7.4	4.6	7.45							
28	晴	3.5	7.3	12.1	7.65							
29	晴	1.0	7.4	3.8	7.72							
30	曇	4.0	7.7	3.7	7.73							
31	曇	4.0	7.8	2.5	7.77							
平均		5.0	9.2	8.5	7.57	57.2	75.5	162	7.3	0.52	<0.02	
最高		13.0	14.4	43.7	7.82	58.5	78.2	176	7.5	0.71	0.02	
最低		-1.5	6.4	2.5	7.32	56.0	72.9	147	7.1	0.32	<0.02	

令和4年12月分

ふじさん工業用水道(東駿河湾)水質試験結果報告書(静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	13.0	15.7	1.4	7.36							
2	曇	10.0	13.7	0.9	7.42							
3	曇	7.0	12.7	1.3	7.52							
4	晴	6.5	11.6	0.7	7.25							
5	曇	10.5	11.7	0.9	7.57							
6	曇	9.0	12.4	1.1	7.48							
7	晴	4.0	12.0	0.7	7.16	53.3	65.0	129	8.5	0.04	<0.02	
8	晴	3.5	11.0	0.6	7.12							
9	晴	7.0	10.8	0.6	7.28							
10	晴	6.0	10.3	0.8	7.10							
11	曇	6.5										断水
12	晴	6.0	10.5	0.7	7.10							
13	雨	7.0	10.1	0.6	7.43							
14	晴	11.0	10.8	0.6	7.45							
15	晴	3.0	10.1	0.5	7.25							
16	晴	2.0	9.2	0.6	7.06							
17	曇	4.0	9.2	0.6	7.24							
18	晴	5.0	9.1	0.5	7.15							
19	晴	-1.5	8.5	0.5	7.20							
20	晴	-1.0	7.7	0.8	7.20							
21	晴	1.0	7.5	1.0	7.24	54.3	67.8	141	8.4	分析装置故障のため鉄・マンガンデータなし		
22	雨	8.0	8.2	1.0	7.62							
23	晴	3.0	7.7	1.5	7.06							
24	晴	3.0	7.0	1.2	7.36							
25	晴	1.0	6.8	0.9	7.23							
26	晴	1.5	6.8	0.8	7.21							
27	晴	6.0	7.5	1.0	7.28							
28	晴	3.5	7.5	1.1	7.51							
29	晴	1.0	7.3	0.9	7.40							
30	曇	4.0	7.6	1.0	7.48							
31	曇	4.0	7.9	0.6	7.57							
平均		5.0	9.6	0.8	7.31	53.8	66.4	135	8.5	0.04	<0.02	
最高		13.0	15.7	1.5	7.62	54.3	67.8	141	8.5	0.04	<0.02	
最低		-1.5	6.8	0.5	7.06	53.3	65.0	129	8.4	0.04	<0.02	