

令和5年7月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	24.5	20.2	22.3	7.81							
2	晴	22.0	19.9	103.0	7.73							
3	曇	23.5	20.8	75.9	7.78							
4	晴	25.0	20.9	31.9	7.71							
5	晴	21.0	20.9	17.0	7.80	46.6	66.7	132	4.0	0.74	0.02	
6	曇	22.0	19.8	14.7	7.78							
7	晴	25.5	22.3	18.2	7.81							
8	曇	24.0	22.0	8.8	7.82							
9	曇	25.5	21.1	7.7	7.84							
10	曇	25.0	21.1	46.7	7.77							
11	曇	25.5	22.7	16.1	7.78							
12	晴	26.5	23.1	12.2	7.80							
13	曇	24.0	22.4	9.6	7.83							
14	曇	23.5	20.6	197.0	7.76							
15	曇	25.5	20.3	39.6	7.77							
16	晴	26.5	20.9	15.8	7.77							
17	晴	26.5	23.5	10.2	7.79							
18	晴	27.0	23.9	12.4	7.79							
19	曇	26.5	23.8	10.9	7.83							
20	晴	26.0	23.5	6.8	7.90	52.8	73.5	129	5.8	0.56	<0.02	
21	晴	27.0	23.2	8.7	7.91							
22	晴	24.5	23.9	91.3	7.68							
23	晴	24.5	23.8	25.9	7.84							
24	晴	26.0	23.5	14.9	7.82							
25	晴	25.0	23.6	12.6	7.73							
26	晴	24.0	23.6	10.5	7.75							
27	曇	26.5	23.6	24.8	7.78							
28	晴	29.0	23.7	28.7	7.80							
29	曇	27.5	24.8	15.1	7.75							
30	晴	26.5	25.2	11.5	7.84							
31	晴	27.0	25.0	8.7	7.93							
平均		25.3	22.5	30.0	7.80	49.7	70.1	131	4.9	0.65	<0.02	
最高		29.0	25.2	197.0	7.93	52.8	73.5	132	5.8	0.74	0.02	
最低		21.0	19.8	6.8	7.68	46.6	66.7	129	4.0	0.56	<0.02	

令和5年7月分

ふじさん工業用水道(東駿河湾)水質試験結果報告書(静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	24.5	21.2	0.5	7.50							
2	晴	22.0	20.6	0.4	7.39							
3	曇	23.5	20.2	0.6	7.52							
4	晴	25.0	21.0	0.9	7.28							
5	晴	21.0	20.7	0.8	7.35	41.2	66.1	112	3.9	0.04	<0.02	
6	曇	22.0	20.5	0.6	7.48							
7	晴	25.5	21.6	0.8	7.52							
8	曇	24.0	22.3	0.7	7.58							
9	曇	25.5	21.6	0.7	7.63							
10	曇	25.0	21.7	1.2	7.50							
11	曇	25.5	22.7	1.1	7.49							
12	晴	26.5	23.3	0.9	7.58							
13	曇	24.0	23.4	0.2	7.64							
14	曇	23.5	21.8	0.4	7.47							
15	曇	25.5	21.4	1.0	7.38							
16	晴	26.5	21.3	0.6	7.47							
17	晴	26.5	22.3	0.5	7.53							
18	晴	27.0	24.0	0.6	7.58							
19	曇	26.5	24.2	0.7	7.60							
20	晴	26.0	24.1	0.6	7.65	48.9	62.4	122	5.5	0.04	<0.02	
21	晴	27.0	23.7	0.9	7.67							
22	晴	24.5	24.0	0.9	7.50							
23	晴	24.5	23.5	1.1	7.49							
24	晴	26.0	23.7	1.7	7.52							
25	晴	25.0	24.3	1.3	7.53							
26	晴	24.0	24.3	0.7	7.59							
27	曇	26.5	24.5	0.9	7.56							
28	晴	29.0	24.0	0.9	7.50							
29	曇	27.5	25.2	1.2	7.53							
30	晴	26.5	25.2	1.0	7.54							
31	晴	27.0	25.0	0.7	7.60							
平均		25.3	22.8	0.8	7.52	45.1	64.2	117	4.7	0.04	<0.02	
最高		29.0	25.2	1.7	7.67	48.9	66.1	122	5.5	0.04	<0.02	
最低		21.0	20.2	0.2	7.28	41.2	62.4	112	3.9	0.04	<0.02	