

令和6年3月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	7.0	9.2	17.4	7.76							
2	晴	6.0	9.2	50.8	7.64							
3	晴	4.5	8.6	17.3	7.76							
4	晴	1.5	8.2	12.3	7.75	52.2	72.5	150	6.4	0.39	0.03	
5	曇	6.5	9.6	23.4	7.78							
6	雨	7.0	8.2	17.6	7.77							
7	雨	6.0	7.9	24.6	7.71							
8	曇	5.0	8.1	14.3	7.80							
9	晴	3.0	9.3	14.4	7.72							
10	晴	4.0	8.7	7.5	7.78							
11	晴	3.0	9.0	5.4	7.79	52.8	66.6	147	6.9	0.17	<0.02	
12	雨	7.0	9.5	11.2	7.75							
13	晴	7.5	7.9	75.3	7.73							
14	晴	5.0	9.2	21.2	7.56							
15	晴	4.5	9.9	10.2	7.78							
16	晴	8.5	10.9	8.3	7.79							
17	晴	8.0	11.5	17.5	7.79							
18	晴	9.5	12.4	6.4	7.79							
19	曇	7.0	9.5	11.1	7.76							
20	晴	3.0	9.5	6.0	7.68							
21	晴	3.0	8.5	10.0	7.74							
22	晴	4.5	8.2	4.6	7.80							
23	曇	3.0	8.9	3.7	7.66							
24	晴	7.0	8.1	5.0	7.72							
25	曇	10.0	9.3	3.3	7.71							
26	雨	10.5	10.3	10.0	7.72							
27	晴	7.5	8.3	346.0	7.70							
28	曇	8.5	9.6	111.0	7.67							
29	雨	14.0	10.9	42.8	7.60							
30	晴	13.5	10.4	350.0	7.68							
31	晴	15.0	11.7	154.0	7.65							
平均		6.8	9.4	45.6	7.73	52.5	69.6	149	6.7	0.28	<0.02	
最高		15.0	12.4	350.0	7.80	52.8	72.5	150	6.9	0.39	0.03	
最低		1.5	7.9	3.3	7.56	52.2	66.6	147	6.4	0.17	<0.02	

令和6年3月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	7.0	9.0	0.8	7.57							
2	晴	6.0	8.6	0.8	7.42							
3	晴	4.5	8.2	0.9	7.45							
4	晴	1.5	8.1	0.8	7.47	49.3	67.0	142	7.4	0.02	<0.02	
5	曇	6.5	9.1	0.6	7.59							
6	雨	7.0	8.8	0.6	7.55							
7	雨	6.0	7.7	0.9	7.47							
8	曇	5.0	7.7	1.0	7.50							
9	晴	3.0	8.7	0.8	7.57							
10	晴	4.0	8.2	0.9	7.62							
11	晴	3.0	8.3	0.5	7.63	50.7	63.4	145	8.1	0.01	<0.02	
12	雨	7.0	8.9	0.5	7.61							
13	晴	7.5	8.9	0.8	7.50							
14	晴	5.0	8.4	1.1	7.29							
15	晴	4.5	9.2	0.8	7.45							
16	晴	8.5	10.4	0.6	7.58							
17	晴	8.0	11.0	0.8	7.55							
18	晴	9.5	12.0	0.5	7.65							
19	曇	7.0	10.9	0.4	7.63							
20	晴	3.0	9.3	0.5	7.53							
21	晴	3.0	9.1	0.4	7.65							
22	晴	4.5	8.2	0.6	7.51							
23	曇	3.0	8.5	0.5	7.56							
24	晴	7.0	8.5	0.5	7.53							
25	曇	10.0	8.7	0.5	7.55							
26	雨	10.5	10.1	0.4	7.60							
27	晴	7.5	9.5	0.7	7.42							
28	曇	8.5	8.9	0.7	7.22							
29	雨	14.0	10.6	0.6	7.28							
30	晴	13.5	10.0	0.6	7.20							
31	晴	15.0	10.5	0.7	7.22							
平均		6.8	9.2	0.7	7.50	50.0	65.2	144	7.8	0.02	<0.02	
最高		15.0	12.0	1.1	7.65	50.7	67.0	145	8.1	0.02	<0.02	
最低		1.5	7.7	0.4	7.20	49.3	63.4	142	7.4	0.01	<0.02	