

令和7年8月分

ふじさん工業用水道（東駿河湾）水質試験結果報告書（静岡庵）

採水時間 8:30

日	天候	気温 ℃	水 質 試 験 結 果 （ 富士川浄水場 分水井 （原水） ）									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	26.0	23.9	31.2	7.76							
2	晴	31.0	24.0	28.5	7.78							
3	晴	29.0	24.7	16.7	8.34							
4	晴	29.0	25.5	18.0	8.12							
5	晴	26.0	27.2	35.4	8.05	55.9	68.5	176	5.7	1.04	0.04	
6	晴	29.0	26.2	11.9	8.28							
7	曇	29.5	26.7	21.5	8.05							
8	晴	28.5	26.1	11.3	7.97							
9	晴	28.0	25.5	25.6	7.91							
10	雨	26.0	23.7	11.9	7.93							
11	雨	26.0	23.3	9.9	7.92							
12	曇	28.0	22.7	131.0	7.85							
13	曇	26.0	22.1	116.0	7.77							
14	曇	24.5	24.4	62.9	7.80							
15	晴	24.5	25.1	13.5	7.93							
16	雨	25.5	24.2	11.7	7.82							
17	曇	26.0	24.2	14.7	7.78							
18	晴	27.0	25.2	8.8	7.87	56.6	67.1	192	6.2	0.31	<0.02	
19	晴	26.5	25.8	9.9	7.87							
20	晴	27.5	25.3	9.1	7.86							
21	晴	27.0	27.1	7.4	7.89							
22	晴	25.0	26.6	9.6	7.85							
23	晴	29.0	25.6	23.7	7.86							
24	曇	28.0	27.4	7.8	7.99							
25	曇	27.0	28.2	6.1	8.10							
26	晴	28.0	26.5	55.4	7.71							
27	晴	32.0	26.6	23.4	7.75							
28	晴	27.0	26.7	15.4	7.90							
29	曇	27.0	26.1	10.2	7.91							
30	晴	30.0	25.0	13.3	7.86							
31	晴	28.5	25.3	9.0	7.89							
平均		27.5	25.4	25.2	7.92	56.2	67.8	184	6.0	0.67	0.03	
最高		32.0	28.2	131.0	8.34	56.6	68.5	192	6.2	1.04	0.04	
最低		24.5	22.1	6.1	7.71	55.9	67.1	176	5.7	0.31	<0.02	

令和7年8月分

ふじさん工業用水道（東駿河湾）水質試験結果報告書（静岡庵）

採水時間 8:30

日	天候	気温 ℃	水 質 試 験 結 果 （ 富士川浄水場 浄水池 （浄水） ）									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	26.0	25.4	0.7	7.62							
2	晴	31.0	24.9	1.0	7.64							
3	晴	29.0	25.1	1.1	7.66							
4	晴	29.0	25.9	1.6	7.69							
5	晴	26.0	26.7	1.3	7.48	49.8	69.7	155	6.2	0.04	<0.02	
6	晴	29.0	25.9	0.8	7.55							
7	曇	29.5	26.9	0.5	7.56							
8	晴	28.5	26.8	0.8	7.57							
9	晴	28.0	25.7	1.0	7.63							
10	雨	26.0	24.7	0.6	7.47							
11	雨	26.0	24.1	0.7	7.52							
12	曇	28.0	23.3	0.6	7.39							
13	曇	26.0	22.7	0.4	7.34							
14	曇	24.5	23.2	0.4	7.48							
15	晴	24.5	24.0	0.2	7.37							
16	雨	25.5	24.8	0.4	7.46							
17	曇	26.0	24.3	0.5	7.53							
18	晴	27.0	24.6	0.3	7.55	51.1	67.9	166	5.8	<0.02	<0.02	
19	晴	26.5	25.8	0.5	7.59							
20	晴	27.5	25.4	0.5	7.62							
21	晴	27.0	27.0	0.5	7.63							
22	晴	25.0	27.0	0.5	7.60							
23	晴	29.0	26.9	0.4	7.64							
24	曇	28.0	27.6	0.7	7.70							
25	曇	27.0	27.8	0.7	7.70							
26	晴	28.0	27.3	1.6	7.52							
27	晴	32.0	27.2	1.1	7.67							
28	晴	27.0	27.0	1.0	7.59							
29	曇	27.0	27.4	0.8	7.53							
30	晴	30.0	26.0	0.9	7.56							
31	晴	28.5	25.9	0.7	7.55							
平均		27.5	25.7	0.7	7.56	50.4	68.8	161	6.0	0.03	<0.02	
最高		32.0	27.8	1.6	7.70	51.1	69.7	166	6.2	0.04	<0.02	
最低		24.5	22.7	0.2	7.34	49.8	67.9	155	5.8	<0.02	<0.02	