

令和8年1月分

ふじさん工業用水道(東駿河湾)水質試験結果報告書(静岡庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	1.5	8.6	2.7	7.59							
2	晴	3.0	8.7	2.4	7.67							
3	晴	3.0	8.2	2.2	7.52							
4	晴	0.0	6.8	1.9	7.61							
5	晴	0.0	7.4	1.6	7.61	58.0	77.2	160	9.5	0.14	<0.02	
6	晴	5.0	8.4	1.8	7.56							
7	曇	3.0	7.9	2.2	7.70							
8	晴	0.0	7.6	2.7	7.60							
9	晴	3.0	8.2	2.8	7.62							
10	晴	0.0	7.0	2.7	7.57							
11	曇	10.5	9.1	2.7	7.72							
12	晴	-2.5	7.8	2.8	7.63							
13	晴	-1.5	7.3	2.2	7.63							
14	晴	0.0	6.5	4.8	7.61							
15	晴	1.0	7.4	2.9	7.56							
16	晴	4.0	7.7	2.7	7.59							
17	晴	2.0	9.5	2.9	7.59							
18	晴	1.5	8.4	3.6	7.60							
19	晴	5.0	9.7	4.0	7.68	59.6	79.6	184	12.1	0.21	<0.02	
20	晴	6.0	9.8	3.2	7.65							
21	曇	3.0	9.7	4.8	7.54							
22	晴	1.5	6.8	3.6	7.63							
23	晴	-3.0	8.1	3.1	7.67							
24	晴	-3.0	7.0	3.7	7.59							
25	晴	-2.0	6.6	5.4	7.64							
26	晴	1.0	7.4	3.3	7.62							
27	晴	1.5	6.6	6.8	7.54							
28	晴	1.5	8.2	4.2	7.62							
29	晴	1.0	7.6	3.7	7.59							
30	晴	-1.5	7.8	3.6	7.55							
31	晴	0.0	7.2	4.1	7.60							
平均		1.4	7.9	3.3	7.61	58.8	78.4	172	10.8	0.18	<0.02	
最高		10.5	9.8	6.8	7.72	59.6	79.6	184	12.1	0.21	<0.02	
最低		-3.0	6.5	1.6	7.52	58.0	77.2	160	9.5	0.14	<0.02	

令和8年1月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (静清庵)

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	1.5	8.8	0.8	7.50							
2	晴	3.0	9.2	0.8	7.53							
3	晴	3.0	8.6	0.8	7.39							
4	晴	0.0	7.4	0.8	7.51							
5	晴	0.0	7.6	0.7	7.53	56.2	78.9	155	9.7	0.05	<0.02	
6	晴	5.0	8.0	0.7	7.42							
7	曇	3.0	7.6	1.0	7.39							
8	晴	0.0	7.1	0.2	7.46							
9	晴	3.0	7.5	0.6	7.41							
10	晴	0.0	7.1	1.0	7.36							
11	曇	10.5	8.6	0.9	7.47							
12	晴	-2.5	7.7	0.9	7.49							
13	晴	-1.5	7.4	0.9	7.50							
14	晴	0.0	6.8	0.9	7.31							
15	晴	1.0	6.9	1.1	7.41							
16	晴	4.0	7.8	1.3	7.39							
17	晴	2.0	8.3	0.9	7.27							
18	晴	1.5	8.1	1.3	7.30							
19	晴	5.0	9.1	1.1	7.41	55.0	79.5	141	12.5	0.04	<0.02	
20	晴	6.0	9.3	0.8	7.37							
21	曇	3.0	9.4	0.7	7.34							
22	晴	1.5	7.5	0.7	7.33							
23	晴	-3.0	7.2	0.6	7.37							
24	晴	-3.0	6.8	0.7	7.32							
25	晴	-2.0	6.4	0.7	7.35							
26	晴	1.0	6.8	0.8	7.36							
27	晴	1.5	6.3	0.4	7.37							
28	晴	1.5	6.9	0.6	7.35							
29	晴	1.0	7.6	0.7	7.37							
30	晴	-1.5	6.9	0.6	7.37							
31	晴	0.0	6.8	0.7	7.40							
平均		1.4	7.7	0.8	7.40	55.6	79.2	148	11.1	0.04	<0.02	
最高		10.5	9.4	1.3	7.53	56.2	79.5	155	12.5	0.05	<0.02	
最低		-3.0	6.3	0.2	7.27	55.0	78.9	141	9.7	0.04	<0.02	