

令和 7年 7月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	29.5	21.2	29.4	7.82							
2	曇	28.0	21.6	20.7	7.79							
3	曇	31.1	21.7	19.8	7.80	35.7	40.9	75	2.9	0.47	0.03	
4	曇	28.5	21.5	17.2	7.84							
5	晴	32.5	21.5	17.5	7.81							
6	晴	33.3	22.5	13.4	7.83							
7	晴	32.5	22.1	13.2	7.80							
8	晴	32.3	22.5	10.7	7.85							
9	晴	32.6	22.8	10.6	7.79							
10	晴	32.6	23.0	9.4	7.83							
11	晴	32.4	23.3	9.5	7.84							
12	曇	27.5	23.0	9.4	7.82							
13	晴	28.6	24.2	8.1	7.85							
14	晴	31.4	23.5	8.4	7.89							
15	雨	26.1	24.0	8.0	7.90							
16	曇	28.1	23.4	22.0	7.76							
17	雨	26.9	23.4	11.3	7.83	37.6	42.0	77	3.8	0.26	0.03	
18	曇	27.5	22.6	27.8	7.76							
19	晴	30.1	23.0	35.5	7.71							
20	晴	28.6	23.0	38.9	7.76							
21	晴	28.6	23.5	34.6	7.75							
22	晴	31.0	22.7	29.6	7.78							
23	晴	31.5	23.2	23.3	7.73							
24	晴	31.5	23.2	20.5	7.69							
25	晴	31.1	23.5	16.7	7.75							
26	晴	29.4	24.0	12.9	7.70							
27	晴	32.9	24.5	12.6	7.82							
28	晴	32.1	23.7	11.3	7.81							
29	晴	32.4	24.0	10.8	7.75							
30	晴	32.5	24.2	8.6	7.82							
31	晴	31.9	24.6	9.6	7.80							
平均		30.5	23.1	17.1	7.80	36.6	41.4	76	3.4	0.36	0.03	
最高		33.3	24.6	38.9	7.90	37.6	42.0	77	3.8	0.47	0.03	
最低		26.1	21.2	8.0	7.69	35.7	40.9	75	2.9	0.26	0.03	

令和 7年 7月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	29.5	23.7	0.9	7.30							
2	曇	28.0	23.6	0.9	7.24							
3	曇	31.1	23.7	0.9	7.29	32.5	40.5	69	5.7	<0.03	<0.02	
4	曇	28.5	24.2	0.6	7.33							
5	晴	32.5	24.0	0.9	7.31							
6	晴	33.3	24.5	0.7	7.39							
7	晴	32.5	24.8	0.4	7.38							
8	晴	32.3	25.1	0.5	7.42							
9	晴	32.6	25.2	0.6	7.36							
10	晴	32.6	25.2	0.6	7.38							
11	晴	32.4	25.5	0.7	7.39							
12	曇	27.5	25.5	0.5	7.35							
13	晴	28.6	26.3	0.7	7.48							
14	晴	31.4	25.7	0.6	7.49							
15	雨	26.1	26.0	0.4	7.51							
16	曇	28.1	25.6	0.5	7.42							
17	雨	26.9	25.2	0.5	7.39	33.0	40.2	55	5.8	0.26	<0.02	
18	曇	27.5	25.2	0.5	7.34							
19	晴	30.1	25.7	0.4	7.29							
20	晴	28.6	25.8	0.3	7.31							
21	晴	28.6	26.5	0.4	7.30							
22	晴	31.0	25.5	0.6	7.28							
23	晴	31.5	25.7	0.5	7.24							
24	晴	31.5	25.8	0.6	7.25							
25	晴	31.1	26.1	0.5	7.28							
26	晴	29.4	26.9	0.5	7.29							
27	晴	32.9	27.7	0.3	7.39							
28	晴	32.1	26.5	0.6	7.39							
29	晴	32.4	26.7	0.3	7.35							
30	晴	32.5	27.0	0.4	7.40							
31	晴	31.9	27.8	0.5	7.43							
平均		30.5	25.6	0.5	7.35	32.8	40.4	62	5.8	0.13	<0.02	
最高		33.3	27.8	0.9	7.51	33.0	40.5	69	5.8	0.26	<0.02	
最低		26.1	23.6	0.3	7.24	32.5	40.2	55	5.7	<0.03	<0.02	