

令和 7年 8月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	31.1	24.5	8.4	7.82							
2	晴	36.9	25.7	8.6	7.85							
3	晴	33.6	25.1	10.6	7.81							
4	曇	31.9	24.7	9.5	7.85							
5	晴	33.3	25.2	8.3	7.91							
6	晴	34.3	25.3	9.1	7.79							
7	曇	30.6	25.4	6.3	7.81	38.6	42.6	68	3.5	0.22	<0.02	
8	晴	28.3	25.0	7.1	7.84							
9	晴	30.6	25.5	7.1	7.86							
10	雨	27.1	25.9	7.0	7.85							
11	雨	27.0	25.0	10.6	7.93							
12	曇	27.9	23.8	55.1	7.82							
13	晴	30.9	24.3	19.3	7.84							
14	晴	28.5	23.6	44.3	7.83							
15	晴	29.7	23.4	83.6	7.83							
16	曇	29.8	23.0	85.8	7.79							
17	晴	28.0	24.0	80.4	7.89							
18	晴	33.3	23.6	64.1	7.85							
19	晴	32.1	23.7	54.4	7.85							
20	晴	31.8	24.0	43.8	7.84	39.4	44.1	92	2.9	0.84	0.06	
21	晴	32.4	24.0	35.9	7.84							
22	晴	30.8	24.1	30.9	7.84							
23	晴	29.0	24.5	25.9	7.88							
24	晴	32.5	24.0	23.1	7.89							
25	曇	32.2	24.2	20.6	7.85							
26	曇	30.7	24.5	18.6	7.82							
27	晴	31.1	24.6	18.1	7.87							
28	晴	32.6	24.5	15.9	7.84							
29	晴	30.5	24.7	13.8	7.87							
30	晴	32.0	25.0	14.1	7.82							
31	晴	33.0	25.3	12.0	7.86							
平均		31.1	24.5	27.5	7.85	39.0	43.4	80	3.2	0.53	0.03	
最高		36.9	25.9	85.8	7.93	39.4	44.1	92	3.5	0.84	0.06	
最低		27.0	23.0	6.3	7.79	38.6	42.6	68	2.9	0.22	<0.02	

令和 7年 8月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	31.1	27.4	0.4	7.34							
2	晴	36.9	28.4	0.4	7.35							
3	晴	33.6	28.1	0.5	7.40							
4	曇	31.9	27.5	0.4	7.39							
5	晴	33.3	27.5	0.6	7.44							
6	晴	34.3	27.7	0.6	7.32							
7	曇	30.6	27.7	0.6	7.36	36.0	42.4	62	5.8	0.05	<0.02	
8	晴	28.3	27.5	0.6	7.38							
9	晴	30.6	27.5	0.5	7.41							
10	雨	27.1	28.0	0.4	7.44							
11	雨	27.0	27.0	0.8	7.45							
12	曇	27.9	26.2	0.5	7.38							
13	晴	30.9	26.3	0.7	7.26							
14	晴	28.5	26.3	0.8	7.30							
15	晴	29.7	26.2	0.7	7.25							
16	曇	29.8	26.0	0.9	7.29							
17	晴	28.0	26.0	0.7	7.20							
18	晴	33.3	26.2	0.8	7.26							
19	晴	32.1	26.3	0.9	7.19							
20	晴	31.8	26.6	1.0	7.21	34.5	43.8	63	6.6	0.08	0.05	
21	晴	32.4	26.7	1.0	7.22							
22	晴	30.8	26.7	1.0	7.29							
23	晴	29.0	26.8	0.7	7.31							
24	晴	32.5	26.5	0.8	7.35							
25	曇	32.2	26.7	0.7	7.34							
26	曇	30.7	26.7	0.9	7.28							
27	晴	31.1	27.0	0.9	7.34							
28	晴	32.6	27.0	0.9	7.38							
29	晴	30.5	26.9	0.7	7.37							
30	晴	32.0	27.5	0.7	7.35							
31	晴	33.0	27.7	0.7	7.40							
平均		31.1	27.0	0.7	7.33	35.2	43.1	62	6.2	0.06	0.02	
最高		36.9	28.4	1.0	7.45	36.0	43.8	63	6.6	0.08	0.05	
最低		27.0	26.0	0.4	7.19	34.5	42.4	62	5.8	0.05	<0.02	