

令和 7年 9月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	32.3	24.7	10.5	7.88							
2	晴	32.6	25.0	9.1	7.95							
3	晴	31.2	25.2	7.2	7.89							
4	曇	30.3	25.2	6.9	7.91	42.9	48.4	93	3.4	0.21	<0.02	
5	雨	26.2	25.0	7.2	7.91							
6	曇	27.6	24.6	63.3	7.80							
7	晴	29.3	24.6	24.1	7.85							
8	晴	33.0	23.5	69.9	7.79							
9	晴	31.7	23.8	52.4	7.76							
10	晴	32.1	23.7	43.1	7.78							
11	曇	30.6	23.8	34.0	7.84							
12	曇	28.4	23.8	26.8	7.71							
13	雨	25.5	24.0	19.1	7.76							
14	曇	29.5	24.3	20.6	7.86							
15	晴	32.0	23.0	17.6	7.82							
16	晴	31.3	23.2	16.3	7.74							
17	晴	29.9	23.6	15.7	7.82							
18	曇	29.6	24.0	15.6	7.87	39.8	43.9	82	3.1	0.56	0.03	
19	曇	25.6	23.5	16.4	7.84							
20	雨	24.5	23.5	13.8	7.92							
21	晴	26.1	23.6	11.5	7.89							
22	晴	23.9	23.3	9.1	7.87							
23	晴	25.5	23.5	9.0	7.89							
24	晴	24.9	23.1	9.5	7.92							
25	曇	25.8	23.0	12.4	7.90							
26	晴	29.9	22.9	12.9	7.76							
27	晴	26.6	23.5	11.6	7.86							
28	晴	28.9	23.8	12.1	7.92							
29	雨	24.5	22.5	11.6	7.89							
30	晴	26.3	22.7	10.6	7.90							
平均		28.5	23.8	20.0	7.85	41.4	46.2	88	3.2	0.38	<0.02	
最高		33.0	25.2	69.9	7.95	42.9	48.4	93	3.4	0.56	0.03	
最低		23.9	22.5	6.9	7.71	39.8	43.9	82	3.1	0.21	<0.02	

令和 7年 9月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	32.3	27.1	0.5	7.41							
2	晴	32.6	27.2	0.8	7.50							
3	晴	31.2	27.3	0.5	7.45							
4	曇	30.3	27.5	0.7	7.56	39.0	47.4	86	5.7	0.08	<0.02	
5	雨	26.2	27.2	0.3	7.52							
6	曇	27.6	27.0	0.5	7.44							
7	晴	29.3	27.1	0.6	7.42							
8	晴	33.0	26.3	0.5	7.35							
9	晴	31.7	26.3	0.8	7.26							
10	晴	32.1	26.2	0.8	7.27							
11	曇	30.6	26.2	0.9	7.34							
12	曇	28.4	26.0	0.9	7.25							
13	雨	25.5	26.0	0.6	7.28							
14	曇	29.5	26.6	0.4	7.30							
15	晴	32.0	25.0	0.5	7.30							
16	晴	31.3	25.5	0.7	7.30							
17	晴	29.9	25.6	0.3	7.31							
18	曇	29.6	26.1	0.8	7.45	35.1	43.0	72	5.6	0.04	<0.02	
19	曇	25.6	25.7	0.6	7.39							
20	雨	24.5	26.4	0.4	7.40							
21	晴	26.1	25.5	0.4	7.41							
22	晴	23.9	25.2	0.4	7.40							
23	晴	25.5	25.2	0.5	7.42							
24	晴	24.9	24.7	0.4	7.52							
25	曇	25.8	24.5	0.4	7.51							
26	晴	29.9	24.6	0.5	7.34							
27	晴	26.6	25.3	0.5	7.42							
28	晴	28.9	25.7	0.3	7.48							
29	雨	24.5	24.4	0.4	7.47							
30	晴	26.3	24.4	0.5	7.40							
平均		28.5	25.9	0.5	7.40	37.0	45.2	79	5.6	0.06	<0.02	
最高		33.0	27.5	0.9	7.56	39.0	47.4	86	5.7	0.08	<0.02	
最低		23.9	24.4	0.3	7.25	35.1	43.0	72	5.6	0.04	<0.02	