

令和 7年 11月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	16.0	17.2	8.0	7.88							
2	晴	18.1	17.9	6.7	7.86							
3	晴	13.1	17.5	5.1	7.87							
4	晴	15.1	16.6	4.6	7.92							
5	晴	13.7	16.6	6.5	7.85							
6	晴	18.5	16.4	6.0	7.82	42.0	47.7	93	4.5	0.22	<0.02	
7	晴	14.9	16.2	9.7	7.85							
8	晴	15.0	16.0	7.2	7.87							
9	雨	15.3	15.8	7.0	7.85							
10	晴	18.9	15.7	8.7	7.88							
11	晴	15.0	15.3	5.8	7.81							
12	曇	12.5	15.1	7.2	7.86							
13	曇	15.3	15.0	6.5	7.77							
14	晴	13.8	14.8	8.6	7.69							
15	晴	13.1	15.2	7.8	7.83							
16	晴	14.1	15.4	9.9	7.86							
17	晴	15.6	14.6	9.5	7.86							
18	晴	14.4	14.4	6.2	7.79							
19	晴	8.6	14.0	8.4	7.84							
20	晴	13.3	13.7	9.2	7.87	42.4	47.0	78	4.9	0.24	<0.02	
21	晴	12.1	13.4	12.0	7.82							
22	晴	13.6	13.3	10.8	7.89							
23	晴	19.3	13.8	8.6	7.91							
24	晴	11.0	13.0	8.9	7.90							
25	曇	12.3	13.3	5.7	7.91							
26	晴	13.2	13.0	6.9	7.93							
27	曇	12.7	12.8	7.2	7.86							
28	晴	13.8	12.8	10.2	7.89							
29	晴	12.6	12.9	10.2	7.91							
30	晴	13.2	12.5	8.5	7.88							
平均		14.3	14.8	7.9	7.86	42.2	47.4	86	4.7	0.23	<0.02	
最高		19.3	17.9	12.0	7.93	42.4	47.7	93	4.9	0.24	<0.02	
最低		8.6	12.5	4.6	7.69	42.0	47.0	78	4.5	0.22	<0.02	

令和 7年 11月分

西遠工業用水道水質試験結果報告書（初生浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	16.0	18.5	0.3	7.48							
2	晴	18.1	18.8	0.4	7.52							
3	晴	13.1	18.3	0.3	7.56							
4	晴	15.1	17.5	0.2	7.58							
5	晴	13.7	17.5	0.2	7.51							
6	晴	18.5	17.3	0.3	7.46	39.4	47.6	79	6.7	<0.03	<0.02	
7	晴	14.9	17.2	0.3	7.49							
8	晴	15.0	17.0	0.1	7.53							
9	雨	15.3	16.8	0.2	7.52							
10	晴	18.9	16.7	0.4	7.57							
11	晴	15.0	16.3	0.2	7.38							
12	曇	12.5	16.1	0.6	7.51							
13	曇	15.3	16.0	0.3	7.38							
14	晴	13.8	15.9	0.4	7.49							
15	晴	13.1	16.2	0.5	7.46							
16	晴	14.1	16.4	0.3	7.50							
17	晴	15.6	15.7	0.2	7.52							
18	晴	14.4	15.5	0.4	7.38							
19	晴	8.6	15.1	0.4	7.54							
20	晴	13.3	14.7	0.3	7.46	39.5	47.2	72	7.4	<0.03	<0.02	
21	晴	12.1	14.4	0.4	7.45							
22	晴	13.6	14.2	0.5	7.50							
23	晴	19.3	14.7	0.2	7.54							
24	晴	11.0	14.2	0.1	7.62							
25	曇	12.3	14.2	0.2	7.55							
26	晴	13.2	13.8	0.3	7.58							
27	曇	12.7	13.7	0.4	7.51							
28	晴	13.8	18.6	0.4	7.51							
29	晴	12.6	13.9	0.3	7.53							
30	晴	13.2	13.6	0.2	7.55							
平均		14.3	16.0	0.3	7.51	39.4	47.4	76	7.0	<0.03	<0.02	
最高		19.3	18.8	0.6	7.62	39.5	47.6	79	7.4	<0.03	<0.02	
最低		8.6	13.6	0.1	7.38	39.4	47.2	72	6.7	<0.03	<0.02	