

様式一工水1 (A4用紙)

令和 8年 3月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	12.3	8.2	5.1	7.95							
2	晴	16.0	8.2	5.1	7.82							
3	雨	10.1	8.4	6.3	7.78							
4	晴	12.1	8.5	5.7	7.85							
5	晴	9.1	8.4	4.8	7.73	42.0	51.5	83	8.6	0.17	<0.02	
6	晴	11.6	8.5	6.2	7.81							
7	晴	10.5	8.5	5.4	7.85							
8	晴	5.8	9.2	5.6	7.84							
9	晴	7.5	8.5	4.9	7.79							
10	晴	10.1	8.5	3.6	7.92							
11	曇	7.2	8.7	3.7	7.83							
12	晴	10.6	8.5	4.0	7.79	41.5	50.0	105	8.0	0.11	0.02	
13	曇	6.5	8.7	5.7	7.83							
14	晴	8.8	9.1	4.7	7.84							
15	晴	9.2	9.0	5.0	7.81							
16	晴	14.5	8.8	4.3	7.79							
17	晴	11.1	9.2	3.1	7.85							
18	晴	14.8	9.3	3.5	7.83							
19	曇	15.7	9.6	4.2	7.89							
20	晴	11.2	10.2	4.4	7.88							
21	晴	9.7	9.5	4.1	7.86							
22	晴	16.5	9.9	3.9	7.97							
23	曇	11.8	9.5	4.3	7.86							
24	晴	17.3	10.0	3.1	7.94							
25	曇	13.0	10.2	3.0	7.91							
26	雨	14.7	10.1	3.3	7.90							
27	晴	15.6	10.3	4.5	7.90							
28	晴	13.0	10.0	4.0	8.08							
29	晴	15.7	10.9	3.6	7.91							
30	曇	16.2	10.7	4.8	7.86							
31	雨	14.4	11.3	2.5	8.03							
平均		12.0	9.3	4.4	7.87	41.8	50.8	94	8.3	0.14	<0.02	
最高		17.3	11.3	6.3	8.08	42.0	51.5	105	8.6	0.17	0.02	
最低		5.8	8.2	2.5	7.73	41.5	50.0	83	8.0	0.11	<0.02	

様式-工水1 (A4用紙)

令和 8年 3月分

西遠工業用水道水質試験結果報告書 (初生浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	12.3	10.0	0.3	7.49							
2	晴	16.0	10.0	0.3	7.41							
3	雨	10.1	10.2	0.6	7.35							
4	晴	12.1	10.2	0.3	7.47							
5	晴	9.1	10.0	0.3	7.37	39.0	51.9	87	11.0	0.05	<0.02	
6	晴	11.6	10.0	0.3	7.41							
7	晴	10.5	10.0	0.3	7.49							
8	晴	5.8	10.6	0.2	7.45							
9	晴	7.5	9.7	0.3	7.45							
10	晴	10.1	9.7	0.4	7.56							
11	曇	7.2	9.8	0.2	7.45							
12	晴	10.6	9.8	0.3	7.40	39.0	50.3	103	11.0	0.05	<0.02	
13	曇	6.5	10.0	0.3	7.48							
14	晴	8.8	10.5	0.3	7.45							
15	晴	9.2	10.5	0.2	7.46							
16	晴	14.5	10.1	0.2	7.39							
17	晴	11.1	10.4	0.2	7.40							
18	晴	14.8	10.7	0.3	7.49							
19	曇	15.7	11.0	0.1	7.52							
20	晴	11.2	11.9	0.2	7.44							
21	晴	9.7	11.4	0.3	7.45							
22	晴	16.5	11.8	0.1	7.46							
23	曇	11.8	11.0	0.1	7.49							
24	晴	17.3	11.2	0.2	7.50							
25	曇	13.0	11.6	0.2	7.42							
26	雨	14.7	11.5	0.2	7.53							
27	晴	15.6	11.7	0.2	7.46							
28	晴	13.0	12.7	0.2	7.58							
29	晴	15.7	12.8	0.2	7.45							
30	曇	16.2	12.5	0.3	7.44							
31	雨	14.4	13.0	0.3	7.61							
平均		12.0	10.8	0.2	7.46	39.0	51.1	95	11.0	0.05	<0.02	
最高		17.3	13.0	0.6	7.61	39.0	51.9	103	11.0	0.05	<0.02	
最低		5.8	9.7	0.1	7.35	39.0	50.3	87	11.0	0.05	<0.02	