

令和2年12月分

中遠工業用水道水質試験結果報告書

検査責任者 東城 大

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	7.8	14.2	2.2	7.75	41.8	46.9	93	5.1	0.12	<0.02	
2	晴	11.9	14.2	2.3	7.79	—	—	—	—	—	—	
3	晴	13.7	14.1	2.2	7.76	—	—	—	—	—	—	
4	晴	10.3	14.0	2.5	7.74	—	—	—	—	—	—	
5	晴	12.0	12.9	2.2	7.60	—	—	—	—	—	—	
6	晴	12.8	12.4	2.2	7.50	—	—	—	—	—	—	
7	晴	11.0	13.8	2.1	7.76	—	—	—	—	—	—	
8	晴	12.4	13.8	2.2	7.78	—	—	—	—	—	—	
9	曇	9.8	13.5	2.3	7.77	—	—	—	—	—	—	
10	晴	9.8	13.5	2.1	7.77	—	—	—	—	—	—	
11	曇	9.6	13.2	2.3	7.77	—	—	—	—	—	—	
12	曇	10.0	11.9	2.1	7.69	—	—	—	—	—	—	
13	晴	14.0	11.8	2.0	7.64	—	—	—	—	—	—	
14	晴	10.3	12.8	1.9	7.76	—	—	—	—	—	—	
15	晴	5.1	12.3	1.8	7.78	41.9	47.4	88	4.8	0.08	<0.02	
16	晴	4.1	12.0	2.3	7.80	—	—	—	—	—	—	
17	晴	2.1	11.5	2.1	7.77	—	—	—	—	—	—	
18	晴	4.2	11.2	2.4	7.79	—	—	—	—	—	—	
19	晴	8.5	10.0	1.7	7.72	—	—	—	—	—	—	
20	晴	4.5	9.6	1.7	7.71	—	—	—	—	—	—	
21	晴	2.7	10.6	1.5	7.70	—	—	—	—	—	—	
22	晴	4.1	10.6	1.7	7.75	—	—	—	—	—	—	
23	晴	6.7	10.7	2.0	7.76	—	—	—	—	—	—	
24	晴	6.3	10.7	1.8	7.73	—	—	—	—	—	—	
25	晴	8.4	10.7	2.2	7.74	—	—	—	—	—	—	
26	晴	7.0	9.1	1.6	7.70	—	—	—	—	—	—	
27	晴	10.8	9.2	1.6	7.72	—	—	—	—	—	—	
28	雨	7.1	10.5	1.7	7.75	—	—	—	—	—	—	
29	曇	8.6	10.4	1.8	7.74	—	—	—	—	—	—	
30	曇	10.9	10.6	1.6	7.67	—	—	—	—	—	—	
31	晴	4.0	8.8	1.6	7.65	—	—	—	—	—	—	
平均		8.4	11.8	2.0	7.73	41.8	47.2	90	5.0	0.10	<0.02	
最高		14.0	14.2	2.5	7.80	41.9	47.4	93	5.1	0.12	<0.02	
最低		2.1	8.8	1.5	7.50	41.8	46.9	88	4.8	0.08	<0.02	

令和2年12月分

中遠工業用水道水質試験結果報告書

検査責任者 東城 大

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	7.8	15.5	0.1	7.54	37.6	44.7	94	8.2	<0.03	<0.02	
2	晴	11.9	15.5	0.2	7.46	—	—	—	—	—	—	
3	晴	13.7	15.5	0.1	7.58	—	—	—	—	—	—	
4	晴	10.3	15.3	0.2	7.51	—	—	—	—	—	—	
5	晴	12.0	15.3	0.2	7.49	—	—	—	—	—	—	
6	晴	12.8	15.2	0.2	7.51	—	—	—	—	—	—	
7	晴	11.0	15.1	0.1	7.56	—	—	—	—	—	—	
8	晴	12.4	15.1	0.1	7.50	—	—	—	—	—	—	
9	曇	9.8	14.9	0.2	7.51	—	—	—	—	—	—	
10	晴	9.8	14.8	0.1	7.46	—	—	—	—	—	—	
11	曇	9.6	14.6	0.2	7.47	—	—	—	—	—	—	
12	曇	10.0	14.7	0.2	7.46	—	—	—	—	—	—	
13	晴	14.0	14.6	0.1	7.52	—	—	—	—	—	—	
14	晴	10.3	14.4	0.1	7.45	—	—	—	—	—	—	
15	晴	5.1	14.0	0.1	7.54	38.0	47.7	76	8.7	<0.03	<0.02	
16	晴	4.1	13.3	0.1	7.51	—	—	—	—	—	—	
17	晴	2.1	12.9	0.2	7.47	—	—	—	—	—	—	
18	晴	4.2	12.7	0.2	7.49	—	—	—	—	—	—	
19	晴	8.5	12.6	0.1	7.49	—	—	—	—	—	—	
20	晴	4.5	10.5	0.1	7.50	—	—	—	—	—	—	
21	晴	2.7	12.1	0.1	7.40	—	—	—	—	—	—	
22	晴	4.1	12.1	0.1	7.50	—	—	—	—	—	—	
23	晴	6.7	12.1	0.1	7.47	—	—	—	—	—	—	
24	晴	6.3	12.2	0.0	7.42	—	—	—	—	—	—	
25	晴	8.4	12.3	0.1	7.45	—	—	—	—	—	—	
26	晴	7.0	12.2	0.2	7.51	—	—	—	—	—	—	
27	晴	10.8	12.0	0.1	7.45	—	—	—	—	—	—	
28	雨	7.1	12.0	0.1	7.47	—	—	—	—	—	—	
29	曇	8.6	12.0	0.1	7.45	—	—	—	—	—	—	
30	曇	10.9	12.2	0.1	7.46	—	—	—	—	—	—	
31	晴	4.0	11.8	0.1	7.41	—	—	—	—	—	—	
平均		8.4	13.5	0.1	7.48	37.8	46.2	85	8.4	<0.03	<0.02	
最高		14.0	15.5	0.2	7.58	38.0	47.7	94	8.7	<0.03	<0.02	
最低		2.1	10.5	0.0	7.40	37.6	44.7	76	8.2	<0.03	<0.02	