

令和5年12月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

| 日 | 水質試験結果(着水井(原水)) | | | | | | | | | | | 備考 |
|----|-----------------|---------|---------|---------|------|---------------|------------|---------------|----------------|-----------|--------------|----|
| | 天候 | 気温 ℃ | 水温 ℃ | 濁度 度 | pH | アルカリ度 mg/l | 硬度 mg/l | 蒸発残留物 mg/l | 塩化物イオン mg/l | 鉄 mg/l | マンガン mg/l | |
| 1 | 晴 | 6.1 | 14.3 | 3.8 | 7.65 | — | — | — | — | — | — | |
| 2 | 晴 | 10.0 | 12.8 | 3.5 | 7.60 | — | — | — | — | — | — | |
| 3 | 晴 | 10.0 | 12.6 | 3.0 | 7.57 | — | — | — | — | — | — | |
| 4 | 晴 | 6.1 | 13.6 | 3.6 | 7.67 | — | — | — | — | — | — | |
| 5 | 曇 | 7.1 | 13.5 | 2.9 | 7.70 | 41.3 | 43.0 | 64 | 4.8 | 0.19 | <0.02 | |
| 6 | 晴 | 9.8 | 13.5 | 8.5 | 7.70 | — | — | — | — | — | — | |
| 7 | 晴 | 10.1 | 13.5 | 2.8 | 7.70 | — | — | — | — | — | — | |
| 8 | 晴 | 8.3 | 13.2 | 2.5 | 7.70 | — | — | — | — | — | — | |
| 9 | 晴 | 13.0 | 12.0 | 2.0 | 7.67 | — | — | — | — | — | — | |
| 10 | 晴 | 14.5 | 12.1 | 2.0 | 7.70 | — | — | — | — | — | — | |
| 11 | 曇 | 12.5 | 13.3 | 2.5 | 7.73 | — | — | — | — | — | — | |
| 12 | 晴 | 14.4 | 13.5 | 2.4 | 7.68 | — | — | — | — | — | — | |
| 13 | 晴 | 9.8 | 13.6 | 4.0 | 7.70 | — | — | — | — | — | — | |
| 14 | 晴 | 9.6 | 13.5 | 2.9 | 7.69 | — | — | — | — | — | — | |
| 15 | 雨 | 12.6 | 13.4 | 2.9 | 7.69 | — | — | — | — | — | — | |
| 16 | 曇 | 17.0 | 12.6 | 2.3 | 7.88 | — | — | — | — | — | — | |
| 17 | 晴 | 6.5 | 11.5 | 2.8 | 7.55 | — | — | — | — | — | — | |
| 18 | 曇 | 3.9 | 12.5 | 2.8 | 7.71 | 40.5 | 43.6 | 95 | 5.0 | 0.19 | <0.02 | |
| 19 | 晴 | 5.1 | 12.3 | 2.6 | 7.67 | — | — | — | — | — | — | |
| 20 | 晴 | 7.6 | 12.4 | 2.4 | 7.65 | — | — | — | — | — | — | |
| 21 | 晴 | 4.7 | 12.0 | 2.7 | 7.71 | — | — | — | — | — | — | |
| 22 | 晴 | 2.3 | 11.5 | 2.3 | 7.64 | — | — | — | — | — | — | |
| 23 | 晴 | 5.0 | 9.8 | 4.6 | 7.69 | — | — | — | — | — | — | |
| 24 | 晴 | 8.0 | 9.6 | 5.7 | 7.65 | — | — | — | — | — | — | |
| 25 | 晴 | 4.8 | 11.0 | 9.2 | 7.67 | — | — | — | — | — | — | |
| 26 | 晴 | 4.1 | 10.8 | 10.6 | 7.63 | — | — | — | — | — | — | |
| 27 | 曇 | 10.8 | 10.8 | 8.6 | 7.64 | — | — | — | — | — | — | |
| 28 | 晴 | 5.5 | 10.5 | 8.3 | 7.59 | — | — | — | — | — | — | |
| 29 | 晴 | 9.5 | 10.5 | 7.6 | 7.51 | — | — | — | — | — | — | |
| 30 | 晴 | 5.5 | 10.5 | 7.8 | 7.64 | — | — | — | — | — | — | |
| 31 | 雨 | 11.0 | 9.3 | 7.1 | 7.61 | — | — | — | — | — | — | |
| 平均 | | 8.6 | 12.1 | 4.4 | 7.66 | 40.9 | 43.3 | 80 | 4.9 | 0.19 | <0.02 | |
| 最高 | | 17.0 | 14.3 | 10.6 | 7.88 | 41.3 | 43.6 | 95 | 5.0 | 0.19 | <0.02 | |
| 最低 | | 2.3 | 9.3 | 2.0 | 7.51 | 40.5 | 43.0 | 64 | 4.8 | 0.19 | <0.02 | |

令和5年12月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

| 日 | 水質試験結果(配水池(浄水)) | | | | | | | | | | | 備考 |
|----|-----------------|---------|---------|---------|------|---------------|------------|---------------|----------------|-----------|--------------|----|
| | 天候 | 気温 ℃ | 水温 ℃ | 濁度 度 | pH | アルカリ度 mg/l | 硬度 mg/l | 蒸発残留物 mg/l | 塩化物イオン mg/l | 鉄 mg/l | マンガン mg/l | |
| 1 | 晴 | 6.1 | 15.1 | 0.2 | 7.55 | — | — | — | — | — | — | |
| 2 | 晴 | 10.0 | 14.8 | 0.2 | 7.41 | — | — | — | — | — | — | |
| 3 | 晴 | 10.0 | 14.6 | 0.3 | 7.53 | — | — | — | — | — | — | |
| 4 | 晴 | 6.1 | 14.3 | <0.1 | 7.53 | — | — | — | — | — | — | |
| 5 | 曇 | 7.1 | 14.3 | 0.1 | 7.58 | 39.8 | 42.0 | 67 | 7.1 | <0.03 | <0.02 | |
| 6 | 晴 | 9.8 | 14.2 | 0.1 | 7.45 | — | — | — | — | — | — | |
| 7 | 晴 | 10.1 | 14.3 | 0.1 | 7.54 | — | — | — | — | — | — | |
| 8 | 晴 | 8.3 | 14.1 | 0.1 | 7.61 | — | — | — | — | — | — | |
| 9 | 晴 | 13.0 | 14.1 | 0.3 | 7.58 | — | — | — | — | — | — | |
| 10 | 晴 | 14.5 | 14.2 | 0.1 | 7.57 | — | — | — | — | — | — | |
| 11 | 曇 | 12.5 | 14.3 | <0.1 | 7.53 | — | — | — | — | — | — | |
| 12 | 晴 | 14.4 | 14.3 | <0.1 | 7.58 | — | — | — | — | — | — | |
| 13 | 晴 | 9.8 | 15.0 | <0.1 | 7.44 | — | — | — | — | — | — | |
| 14 | 晴 | 9.6 | 16.0 | 0.2 | 7.53 | — | — | — | — | — | — | |
| 15 | 雨 | 12.6 | 16.0 | 0.2 | 7.52 | — | — | — | — | — | — | |
| 16 | 曇 | 17.0 | 16.5 | <0.1 | 7.47 | — | — | — | — | — | — | |
| 17 | 晴 | 6.5 | 16.0 | 0.1 | 7.48 | — | — | — | — | — | — | |
| 18 | 曇 | 3.9 | 15.3 | <0.1 | 7.51 | 40.4 | 44.5 | 96 | 7.9 | <0.03 | <0.02 | |
| 19 | 晴 | 5.1 | 15.0 | 0.2 | 7.49 | — | — | — | — | — | — | |
| 20 | 晴 | 7.6 | 15.0 | 0.1 | 7.50 | — | — | — | — | — | — | |
| 21 | 晴 | 4.7 | 14.8 | 0.2 | 7.50 | — | — | — | — | — | — | |
| 22 | 晴 | 2.3 | 14.2 | <0.1 | 7.49 | — | — | — | — | — | — | |
| 23 | 晴 | 5.0 | 13.9 | 0.1 | 7.48 | — | — | — | — | — | — | |
| 24 | 晴 | 8.0 | 13.7 | <0.1 | 7.46 | — | — | — | — | — | — | |
| 25 | 晴 | 4.8 | 13.7 | 0.1 | 7.44 | — | — | — | — | — | — | |
| 26 | 晴 | 4.1 | 13.8 | 0.1 | 7.44 | — | — | — | — | — | — | |
| 27 | 曇 | 10.8 | 13.7 | 0.3 | 7.36 | — | — | — | — | — | — | |
| 28 | 晴 | 5.5 | 15.1 | 0.2 | 7.51 | — | — | — | — | — | — | |
| 29 | 晴 | 9.5 | 12.8 | 0.2 | 7.42 | — | — | — | — | — | — | |
| 30 | 晴 | 5.5 | 12.5 | 0.3 | 7.40 | — | — | — | — | — | — | |
| 31 | 雨 | 11.0 | 12.6 | 0.4 | 7.44 | — | — | — | — | — | — | |
| 平均 | | 8.6 | 14.5 | 0.1 | 7.49 | 40.1 | 43.2 | 82 | 7.5 | <0.03 | <0.02 | |
| 最高 | | 17.0 | 16.5 | 0.4 | 7.61 | 40.4 | 44.5 | 96 | 7.9 | <0.03 | <0.02 | |
| 最低 | | 2.3 | 12.5 | <0.1 | 7.36 | 39.8 | 42.0 | 67 | 7.1 | <0.03 | <0.02 | |