

令和7年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	29.5	26.6	4.4	7.64	—	—	—	—	—	—	
2	晴	31.3	26.8	3.8	7.68	—	—	—	—	—	—	
3	晴	32.3	27.1	3.8	7.63	—	—	—	—	—	—	
4	晴	31.6	27.2	4.3	7.62	—	—	—	—	—	—	
5	晴	31.5	27.2	3.8	7.65	36.1	37.3	68	3.6	0.24	0.03	
6	晴	32.0	27.4	3.5	7.70	—	—	—	—	—	—	
7	曇	30.6	27.5	3.1	7.71	—	—	—	—	—	—	
8	曇	28.6	27.1	2.4	7.63	—	—	—	—	—	—	
9	晴	30.0	27.0	3.0	7.65	—	—	—	—	—	—	
10	雨	28.8	26.8	3.1	7.63	—	—	—	—	—	—	
11	雨	27.0	26.6	6.3	7.61	—	—	—	—	—	—	
12	曇	28.4	26.0	56.8	7.62	—	—	—	—	—	—	
13	晴	30.9	26.1	14.2	7.65	—	—	—	—	—	—	
14	曇	27.9	25.8	20.6	7.64	—	—	—	—	—	—	
15	晴	28.1	25.6	37.4	7.64	—	—	—	—	—	—	
16	曇	29.1	25.8	45.8	7.63	—	—	—	—	—	—	
17	晴	28.5	25.8	42.7	7.61	—	—	—	—	—	—	
18	晴	28.8	25.8	32.8	7.63	—	—	—	—	—	—	
19	晴	28.4	26.0	25.5	7.68	36.3	38.2	106	3.7	1.20	0.05	
20	晴	28.4	26.2	20.2	7.62	—	—	—	—	—	—	
21	晴	29.0	26.3	16.1	7.62	—	—	—	—	—	—	
22	晴	29.4	26.4	13.8	7.64	—	—	—	—	—	—	
23	晴	30.5	26.4	13.5	7.44	—	—	—	—	—	—	
24	晴	31.5	26.5	11.5	7.63	—	—	—	—	—	—	
25	晴	30.6	26.8	9.9	7.63	—	—	—	—	—	—	
26	晴	29.7	26.7	7.9	7.63	—	—	—	—	—	—	
27	晴	30.1	26.8	10.1	7.63	—	—	—	—	—	—	
28	曇	29.7	27.0	7.1	7.51	—	—	—	—	—	—	
29	晴	28.9	26.9	6.4	7.61	—	—	—	—	—	—	
30	晴	31.6	27.0	5.8	7.67	—	—	—	—	—	—	
31	晴	30.9	27.1	5.3	7.66	—	—	—	—	—	—	
平均		29.8	26.6	14.4	7.63	36.2	37.8	87	3.6	0.72	0.04	
最高		32.3	27.5	56.8	7.71	36.3	38.2	106	3.7	1.20	0.05	
最低		27.0	25.6	2.4	7.44	36.1	37.3	68	3.6	0.24	0.03	

令和7年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	29.5	27.1	0.6	7.47	—	—	—	—	—	—	
2	晴	31.3	27.3	0.5	7.50	—	—	—	—	—	—	
3	晴	32.3	27.6	0.5	7.48	—	—	—	—	—	—	
4	晴	31.6	27.8	0.5	7.51	—	—	—	—	—	—	
5	晴	31.5	27.8	0.5	7.42	33.0	37.4	62	8.3	0.05	0.02	
6	晴	32.0	27.9	0.6	7.50	—	—	—	—	—	—	
7	曇	30.6	28.0	0.6	7.57	—	—	—	—	—	—	
8	曇	28.6	27.6	0.6	7.58	—	—	—	—	—	—	
9	晴	30.0	27.6	0.8	7.60	—	—	—	—	—	—	
10	雨	28.8	27.5	0.6	7.62	—	—	—	—	—	—	
11	雨	27.0	27.5	0.6	7.60	—	—	—	—	—	—	
12	曇	28.4	27.3	0.7	7.58	—	—	—	—	—	—	
13	晴	30.9	27.1	0.8	7.59	—	—	—	—	—	—	
14	曇	27.9	26.9	0.9	7.56	—	—	—	—	—	—	
15	晴	28.1	26.8	0.9	7.52	—	—	—	—	—	—	
16	曇	29.1	27.0	0.9	7.50	—	—	—	—	—	—	
17	晴	28.5	27.0	0.9	7.51	—	—	—	—	—	—	
18	晴	28.8	27.0	1.0	7.51	—	—	—	—	—	—	
19	晴	28.4	26.9	1.1	7.53	33.6	37.9	69	6.7	0.05	0.04	
20	晴	28.4	27.0	0.9	7.49	—	—	—	—	—	—	
21	晴	29.0	27.1	0.9	7.49	—	—	—	—	—	—	
22	晴	29.4	27.1	0.9	7.47	—	—	—	—	—	—	
23	晴	30.5	27.3	1.0	7.55	—	—	—	—	—	—	
24	晴	31.5	27.4	0.9	7.52	—	—	—	—	—	—	
25	晴	30.6	27.6	1.0	7.70	—	—	—	—	—	—	
26	晴	29.7	27.5	0.8	7.50	—	—	—	—	—	—	
27	晴	30.1	27.6	0.9	7.53	—	—	—	—	—	—	
28	曇	29.7	27.6	0.8	7.36	—	—	—	—	—	—	
29	晴	28.9	27.5	0.8	7.54	—	—	—	—	—	—	
30	晴	31.6	27.7	0.7	7.59	—	—	—	—	—	—	
31	晴	30.9	27.8	0.6	7.53	—	—	—	—	—	—	
平均		29.8	27.4	0.8	7.53	33.3	37.6	66	7.5	0.05	0.03	
最高		32.3	28.0	1.1	7.70	33.6	37.9	69	8.3	0.05	0.04	
最低		27.0	26.8	0.5	7.36	33.0	37.4	62	6.7	0.05	0.02	