

令和7年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))										備考
	天候	気温	水温	濁度	pH	アルカリ度	硬度	蒸発残留物	塩化物イオン	鉄	
		°C	°C	度		mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
1	晴	15.3	19.8	1.7	7.76	—	—	—	—	—	—
2	晴	16.5	19.7	1.7	7.75	—	—	—	—	—	—
3	曇	14.0	19.5	1.6	7.74	—	—	—	—	—	—
4	晴	13.3	19.2	1.7	7.72	—	—	—	—	—	—
5	曇	13.9	19.0	1.6	7.72	42.6	45.9	80	4.3	0.10	<0.02
6	晴	15.8	19.0	1.9	7.74	—	—	—	—	—	—
7	晴	14.4	18.8	1.6	7.72	—	—	—	—	—	—
8	晴	15.6	18.6	1.5	7.74	—	—	—	—	—	—
9	雨	15.8	18.6	1.6	7.71	—	—	—	—	—	—
10	晴	17.0	18.6	1.6	7.74	—	—	—	—	—	—
11	晴	12.0	18.1	1.6	7.75	—	—	—	—	—	—
12	曇	11.5	17.8	1.8	7.72	—	—	—	—	—	—
13	曇	13.0	17.7	1.9	7.71	—	—	—	—	—	—
14	晴	12.0	17.5	1.9	7.74	—	—	—	—	—	—
15	晴	13.1	15.5	2.2	7.85	—	—	—	—	—	—
16	晴	14.8	17.5	1.9	7.74	—	—	—	—	—	—
17	晴	12.7	17.4	2.4	7.72	—	—	—	—	—	—
18	晴	13.0	17.2	2.3	7.72	41.9	45.8	72	5.3	0.14	<0.02
19	晴	8.3	16.6	2.2	7.74	—	—	—	—	—	—
20	晴	8.1	16.3	2.4	7.69	—	—	—	—	—	—
21	晴	11.0	16.1	2.4	7.71	—	—	—	—	—	—
22	晴	12.5	16.0	2.5	7.72	—	—	—	—	—	—
23	晴	12.8	16.0	2.4	7.70	—	—	—	—	—	—
24	晴	12.4	15.8	2.4	7.71	—	—	—	—	—	—
25	曇	13.0	15.9	2.3	7.70	—	—	—	—	—	—
26	晴	11.0	15.5	2.3	7.67	—	—	—	—	—	—
27	晴	11.3	15.5	2.3	7.67	—	—	—	—	—	—
28	晴	12.6	15.5	2.5	7.69	—	—	—	—	—	—
29	晴	10.1	15.2	2.2	7.73	—	—	—	—	—	—
30	晴	9.6	15.1	2.2	7.69	—	—	—	—	—	—
平均		12.9	17.3	2.0	7.72	42.2	45.8	76	4.8	0.12	<0.02
最高		17.0	19.8	2.5	7.85	42.6	45.9	80	5.3	0.14	<0.02
最低		8.1	15.1	1.5	7.67	41.9	45.8	72	4.3	0.10	<0.02

令和7年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))										備考
	天候	気温	水温	濁度	pH	アルカリ度	硬度	蒸発残留物	塩化物イオン	鉄	
		°C	°C	度		mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
1	晴	15.3	21.1	0.2	7.67	—	—	—	—	—	—
2	晴	16.5	21.1	0.2	7.66	—	—	—	—	—	—
3	曇	14.0	20.8	0.2	7.63	—	—	—	—	—	—
4	晴	13.3	20.5	0.2	7.63	—	—	—	—	—	—
5	曇	13.9	20.3	0.3	7.53	42.6	46.1	86	9.6	<0.03	<0.02
6	晴	15.8	20.2	0.3	7.57	—	—	—	—	—	—
7	晴	14.4	20.1	0.2	7.58	—	—	—	—	—	—
8	晴	15.6	20.1	0.3	7.60	—	—	—	—	—	—
9	雨	15.8	20.0	0.3	7.59	—	—	—	—	—	—
10	晴	17.0	20.0	0.3	7.59	—	—	—	—	—	—
11	晴	12.0	19.5	0.2	7.60	—	—	—	—	—	—
12	曇	11.5	19.2	0.2	7.61	—	—	—	—	—	—
13	曇	13.0	19.2	0.2	7.64	—	—	—	—	—	—
14	晴	12.0	19.0	0.3	7.58	—	—	—	—	—	—
15	晴	13.1	17.8	0.1	7.59	—	—	—	—	—	—
16	晴	14.8	19.0	0.2	7.62	—	—	—	—	—	—
17	晴	12.7	18.8	0.2	7.55	—	—	—	—	—	—
18	晴	13.0	18.8	0.2	7.58	42.0	45.9	68	7.3	<0.03	<0.02
19	晴	8.3	18.1	<0.1	7.64	—	—	—	—	—	—
20	晴	8.1	17.8	0.2	7.67	—	—	—	—	—	—
21	晴	11.0	17.7	0.1	7.59	—	—	—	—	—	—
22	晴	12.5	17.5	0.2	7.62	—	—	—	—	—	—
23	晴	12.8	17.6	<0.1	7.59	—	—	—	—	—	—
24	晴	12.4	17.5	0.2	7.59	—	—	—	—	—	—
25	曇	13.0	17.5	<0.1	7.56	—	—	—	—	—	—
26	晴	11.0	17.2	0.1	7.48	—	—	—	—	—	—
27	晴	11.3	17.1	<0.1	7.53	—	—	—	—	—	—
28	晴	12.6	17.3	<0.1	7.52	—	—	—	—	—	—
29	晴	10.1	16.8	0.1	7.60	—	—	—	—	—	—
30	晴	9.6	16.7	0.1	7.56	—	—	—	—	—	—
平均		12.9	18.8	0.2	7.59	42.3	46.0	77	8.4	<0.03	<0.02
最高		17.0	21.1	0.3	7.67	42.6	46.1	86	9.6	<0.03	<0.02
最低		8.1	16.7	<0.1	7.48	42.0	45.9	68	7.3	<0.03	<0.02