

令和 2年 11月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸 発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	22.6	13.9	0.4	7.56							
2	晴	27.2	13.9	0.2	7.71							
3	晴	22.0	13.7	0.3	7.58							
4	晴	18.2	13.4	0.3	7.62							
5	晴	20.5	13.3	0.2	7.68							
6	晴	21.5	13.5	0.3	7.66							
7	曇	22.5	13.3	0.3	7.60							
8	晴	23.0	13.3	0.4	7.59							
9	晴	20.6	13.1	0.3	7.62	20.4	23.1	24.0	4.1	0.06	<0.02	
10	晴	19.0	13.0	0.2	7.60							
11	晴	17.5	13.0	0.2	7.57							
12	曇	18.5	12.9	0.2	7.56							
13	晴	23.9	12.8	0.2	7.63							
14	晴	21.0	12.6	0.2	7.55							
15	晴	23.4	12.5	0.2	7.58							
16	晴	25.1	12.5	0.2	7.64							
17	晴	23.5	12.5	0.2	7.64							
18	晴	26.6	12.8	0.2	7.72							
19	晴	28.0	13.2	0.2	7.79							
20	雨	20.4	13.5	0.3	7.73							
21	晴	16.3	13.4	0.2	7.60							
22	晴	17.9	13.8	0.4	7.63							
23	晴	18.1	14.1	0.3	7.63							
24	晴	17.9	13.6	0.3	7.61	19.8	23.4	40.0	4.3	<0.03	<0.02	
25	晴	16.0	13.4	0.3	7.56							
26	晴	14.6	12.5	0.6	7.52							
27	晴	13.9	12.2	0.4	7.63							
28	晴	14.0	12.1	0.4	7.44							
29	晴	13.0	12.7	0.3	7.53							
30	晴	10.0	10.6	0.2	7.67							
平均		19.9	13.0	0.3	7.62	20.1	23.2	32.0	4.2	0.03	<0.02	
最高		28.0	14.1	0.6	7.79	20.4	23.4	40.0	4.3	0.06	<0.02	
最低		10.0	10.6	0.2	7.44	19.8	23.1	24.0	4.1	<0.03	<0.02	

令和 2年 11月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	22.6	14.3	0.4	7.62							
2	晴	27.2	14.3	0.2	7.76							
3	晴	22.0	14.2	0.4	7.68							
4	晴	18.2	13.8	0.3	7.73							
5	晴	20.5	13.5	0.3	7.70							
6	晴	21.5	13.5	0.3	7.64							
7	曇	22.5	13.7	0.3	7.68							
8	晴	23.0	13.7	0.3	7.68							
9	晴	20.6	13.5	0.3	7.69	20.8	22.5	20.0	4.1	0.05	<0.02	
10	晴	19.0	13.2	0.1	7.67							
11	晴	17.5	13.1	0.3	7.63							
12	曇	18.5	13.2	0.2	7.66							
13	晴	23.9	13.2	0.3	7.69							
14	晴	21.0	13.1	0.3	7.64							
15	晴	23.4	12.9	0.3	7.65							
16	晴	25.1	13.1	0.2	7.69							
17	晴	23.5	12.9	0.2	7.72							
18	晴	26.6	13.2	0.2	7.79							
19	晴	28.0	13.5	0.2	7.83							
20	雨	20.4	14.0	0.3	7.76							
21	晴	16.3	13.9	0.3	7.68							
22	晴	17.9	13.8	0.3	7.72							
23	晴	18.1	14.1	0.3	7.62							
24	晴	17.9	13.6	0.3	7.70	19.9	22.7	38.0	4.1	<0.03	<0.02	
25	晴	16.0	13.8	0.3	7.67							
26	晴	14.6	13.3	0.4	7.41							
27	晴	13.9	12.8	0.4	7.64							
28	晴	14.0	12.6	0.4	7.59							
29	晴	13.0	13.1	0.3	7.58							
30	晴	10.0	11.4	0.3	7.66							
平均		19.9	13.4	0.3	7.67	20.4	22.6	29.0	4.1	<0.03	<0.02	
最高		28.0	14.3	0.4	7.83	20.8	22.7	38.0	4.1	0.05	<0.02	
最低		10.0	11.4	0.1	7.41	19.9	22.5	20.0	4.1	<0.03	<0.02	