

令和 2年 12月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	12.4	10.2	0.3	7.74							
2	曇	11.0	9.7	0.3	7.64							
3	晴	13.5	9.9	0.3	7.69							
4	晴	11.4	10.2	0.1	7.63							
5	晴	10.7	10.5	0.3	7.50							
6	晴	13.8	12.1	0.4	7.53							
7	晴	13.1	10.8	0.3	7.57	18.4	21.2	42.0	4.3	0.03	<0.02	
8	晴	12.8	10.8	0.3	7.55							
9	曇	9.4	10.5	0.3	7.59							
10	晴	11.3	10.4	0.3	7.54							
11	曇	11.9	10.3	0.4	7.56							
12	曇	11.3	10.3	0.3	7.54							
13	晴	12.0	11.4	0.3	7.55							
14	晴	10.6	10.1	0.3	7.51							
15	晴	5.7	10.1	0.3	7.55							
16	晴	5.5	9.4	0.2	7.55							
17	晴	4.0	9.0	0.4	7.49							
18	晴	6.3	8.6	0.3	7.47							
19	晴	6.6	8.3	0.4	7.39							
20	晴	3.6	9.0	0.3	7.41							
21	晴	6.1	7.5	0.4	7.42	18.2	20.9	64.0	3.9	0.09	<0.02	
22	晴	8.5	7.7	0.3	7.55							
23	晴	8.8	7.7	0.4	7.54							
24	曇	10.5	7.7	0.4	7.59							
25	曇	8.4	8.0	0.5	7.61							
26	晴	5.2	8.1	0.4	7.48							
27	晴	5.2	9.3	0.3	7.62							
28	雨	7.7	8.5	0.4	7.57							
29	晴	7.9	8.5	0.4	7.51							
30	雨	8.9	9.6	0.4	7.60							
31	晴	2.3	8.7	0.5	7.49							
平均		8.9	9.4	0.3	7.55	18.3	21.0	53.0	4.1	0.06	<0.02	
最高		13.8	12.1	0.5	7.74	18.4	21.2	64.0	4.3	0.09	<0.02	
最低		2.3	7.5	0.1	7.39	18.2	20.9	42.0	3.9	0.03	<0.02	

令和 2年 12月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	12.4	10.8	0.4	7.78							
2	曇	11.0	10.4	0.2	7.71							
3	晴	13.5	10.1	0.3	7.77							
4	晴	11.4	10.2	0.3	7.71							
5	晴	10.7	10.6	0.3	7.62							
6	晴	13.8	11.9	0.3	7.64							
7	晴	13.1	10.8	0.2	7.64	18.8	21.0	46.0	4.3	0.04	<0.02	
8	晴	12.8	10.9	0.3	7.63							
9	曇	9.4	10.7	0.3	7.63							
10	晴	11.3	10.4	0.3	7.58							
11	曇	11.9	10.4	0.3	7.62							
12	曇	11.3	10.4	0.3	7.57							
13	晴	12.0	11.4	0.4	7.62							
14	晴	10.6	10.2	0.3	7.60							
15	晴	5.7	10.1	0.3	7.63							
16	晴	5.5	9.6	0.2	7.60							
17	晴	4.0	9.1	0.3	7.56							
18	晴	6.3	8.8	0.4	7.55							
19	晴	6.6	8.5	0.4	7.50							
20	晴	3.6	9.1	0.3	7.52							
21	晴	6.1	7.8	0.4	7.53	18.5	21.0	56.0	4.2	0.03	<0.02	
22	晴	8.5	7.6	0.3	7.57							
23	晴	8.8	7.8	0.4	7.60							
24	曇	10.5	7.8	0.4	7.62							
25	曇	8.4	7.8	0.4	7.63							
26	晴	5.2	7.9	0.3	7.57							
27	晴	5.2	9.0	0.3	7.60							
28	雨	7.7	8.5	0.3	7.59							
29	晴	7.9	8.5	0.4	7.62							
30	雨	8.9	9.7	0.4	7.65							
31	晴	2.3	8.5	0.4	7.60							
平均		8.9	9.5	0.3	7.61	18.6	21.0	51.0	4.2	0.04	<0.02	
最高		13.8	11.9	0.4	7.78	18.8	21.0	56.0	4.3	0.04	<0.02	
最低		2.3	7.6	0.2	7.50	18.5	21.0	46.0	4.2	0.03	<0.02	