

令和 3年 2月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	6.7	7.5	0.5	7.47	18.7	22.4	38.0	5.1	<0.03	<0.02	
2	曇	8.4	7.7	0.5	7.48							
3	曇	4.9	7.2	0.4	7.49							
4	晴	6.6	6.9	0.5	7.53							
5	晴	5.0	6.8	0.5	7.52							
6	曇	8.5	7.1	0.8	7.52							
7	晴	10.2	7.2	0.5	7.48							
8	晴	6.8	7.1	0.4	7.53							
9	晴	2.0	6.9	0.5	7.55							
10	晴	6.8	6.9	0.4	7.55							
11	晴	6.0	7.1	0.4	7.51							
12	曇	5.0	7.2	0.4	7.56							
13	曇	8.1	7.5	0.4	7.52							
14	晴	15.0	7.9	0.6	7.55							
15	雨	12.0	8.5	0.4	7.56	17.4	19.5	51.0	4.0	0.04	<0.02	
16	晴	9.1	8.8	0.5	7.51							
17	曇	4.8	8.7	0.6	7.50							
18	晴	1.0	8.2	0.8	7.56							
19	晴	1.8	7.9	0.7	7.54							
20	晴	8.7	7.7	0.6	7.54							
21	晴	14.5	7.8	0.5	7.51							
22	晴	15.2	7.9	0.5	7.54							
23	晴	13.0	8.2	0.5	7.55							
24	晴	4.5	8.0	0.4	7.60							
25	晴	8.0	7.9	0.4	7.60							
26	雨	8.2	8.3	0.4	7.62							
27	晴	6.0	8.2	0.6	7.52							
28	晴	9.0	8.2	0.4	7.53							
平均		7.7	7.7	0.5	7.53	18.0	21.0	44.5	4.6	<0.03	<0.02	
最高		15.2	8.8	0.8	7.62	18.7	22.4	51.0	5.1	0.04	<0.02	
最低		1.0	6.8	0.4	7.47	17.4	19.5	38.0	4.0	<0.03	<0.02	