

令和 3年 3月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	13.4	8.3	0.5	7.50	19.0	21.5	37	4.1	0.04	<0.02	
2	雨	15.2	8.9	0.6	7.52							
3	晴	6.0	8.6	5.5	7.42							
4	曇	9.5	9.7	2.4	7.30							
5	雨	11.0	9.8	2.9	7.26							
6	晴	12.1	9.8	2.1	7.18							
7	曇	7.3	10.4	1.0	7.27							
8	雨	9.5	10.2	0.7	7.32							
9	晴	11.8	10.3	0.7	7.37							
10	晴	12.5	10.6	0.4	7.36							
11	晴	12.0	10.6	0.4	7.42							
12	曇	11.5	10.5	0.3	7.34							
13	曇	13.5	10.8	0.3	7.34							
14	晴	9.4	10.1	2.1	7.26							
15	晴	10.0	10.7	2.0	7.32	14.1	16.2	53	3.0	0.03	<0.02	
16	晴	14.3	10.5	1.9	7.20							
17	晴	12.6	10.3	1.7	7.19							
18	晴	14.0	10.6	0.8	7.20							
19	晴	13.5	10.8	0.5	7.26							
20	晴	15.8	11.1	0.5	7.34							
21	雨	17.0	11.4	0.4	7.36							
22	晴	10.9	12.0	7.7	6.77							
23	晴	9.0	11.2	1.3	7.06							
24	晴	15.0	11.4	1.0	7.06							
25	曇	13.0	12.1	0.8	7.20							
26	晴	15.0	11.8	0.6	7.25							
27	曇	14.3	11.5	0.6	7.25							
28	曇	17.1	11.5	0.5	7.36							
29	晴	16.6	12.0	0.5	7.41							
30	晴	18.2	12.1	0.7	7.29							
31	晴	16.4	12.9	1.0	7.36							
平均		12.8	10.7	1.4	7.28	16.6	18.8	45	3.6	0.04	<0.02	
最高		18.2	12.9	7.7	7.52	19.0	21.5	53	4.1	0.04	<0.02	
最低		6.0	8.3	0.3	6.77	14.1	16.2	37	3.0	0.03	<0.02	

令和 3年 3月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	13.4	8.5	0.5	7.57	18.8	22.0	39	4.2	<0.03	<0.02	
2	雨	15.2	8.9	0.4	7.53							
3	晴	6.0	8.6	0.5	7.37							
4	曇	9.5	9.1	1.5	7.06							
5	雨	11.0	9.7	0.9	6.77							
6	晴	12.1	9.9	2.2	7.10							
7	曇	7.3	9.8	1.6	7.17							
8	雨	9.5	10.1	1.0	7.21							
9	晴	11.8	10.2	0.5	7.26							
10	晴	12.5	10.4	0.5	7.33							
11	晴	12.0	10.5	0.5	7.40							
12	曇	11.5	10.8	0.3	7.38							
13	曇	13.5	10.8	0.4	7.36							
14	晴	9.4	10.5	0.7	7.34							
15	晴	10.0	10.1	1.5	7.31	16.0	17.7	58	3.5	<0.03	<0.02	
16	晴	14.3	10.5	1.6	7.24							
17	晴	12.6	10.4	1.8	7.18							
18	晴	14.0	10.4	1.2	7.21							
19	晴	13.5	10.9	0.6	7.24							
20	晴	15.8	11.2	0.5	7.23							
21	雨	17.0	12.0	0.5	7.41							
22	晴	10.9	11.9	0.8	7.10							
23	晴	9.0	11.9	2.0	6.91							
24	晴	15.0	11.5	1.2	7.03							
25	曇	13.0	12.0	0.9	7.12							
26	晴	15.0	11.9	0.7	7.18							
27	曇	14.3	12.0	0.7	7.23							
28	曇	17.1	12.1	0.6	7.31							
29	晴	16.6	12.3	0.5	7.28							
30	晴	18.2	12.5	0.6	7.38							
31	晴	16.4	12.7	1.2	7.26							
平均		12.8	10.8	0.9	7.24	17.4	19.8	48	3.8	<0.03	<0.02	
最高		18.2	12.7	2.2	7.57	18.8	22.0	58	4.2	<0.03	<0.02	
最低		6.0	8.5	0.3	6.77	16.0	17.7	39	3.5	<0.03	<0.02	