

令和 3年 7月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸 発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	20.0	19.6	0.9	7.23	17.8	19.4	45	2.6	<0.03	<0.02	
2	雨	23.0	18.5	3.0	6.98							
3	雨	24.0	18.6	2.3	6.66							
4	曇	22.0	18.8	6.9	6.45							
5	曇	27.2	19.1	5.1	6.47							
6	曇	26.5	18.5	1.4	6.63							
7	雨	26.2	18.6	1.2	6.65							
8	曇	25.0	18.9	0.8	6.75							
9	晴	27.8	18.9	0.7	6.79							
10	晴	29.6	19.8	1.0	7.24							
11	晴	29.9	20.9	0.9	7.54							
12	晴	29.5	21.9	0.9	7.64							
13	晴	27.5	22.1	0.7	7.46							
14	曇	26.0	21.9	0.7	7.75							
15	曇	25.1	21.8	1.8	7.34	17.6	18.4	32	2.8	<0.03	<0.02	
16	晴	26.5	21.7	1.5	7.64							
17	晴	28.6	21.8	1.2	7.81							
18	晴	29.3	22.5	1.1	8.02							
19	晴	31.0	23.1	0.8	8.05							
20	晴	30.1	23.2	0.9	8.26							
21	晴	29.5	23.4	0.7	8.12							
22	晴	30.3	22.9	1.7	7.60							
23	晴	31.0	22.3	1.6	7.41							
24	晴	30.5	22.1	1.4	7.28							
25	晴	30.0	22.1	1.3	7.24							
26	曇	28.1	22.2	1.2	7.25							
27	晴	29.5	22.1	2.0	7.23							
28	曇	28.5	21.7	2.0	7.23							
29	晴	29.0	22.0	1.8	7.48							
30	晴	29.0	22.2	4.2	7.63							
31	晴	29.5	22.0	5.0	7.56							
平均		27.7	21.1	1.8	7.34	17.7	18.9	38	2.7	<0.03	<0.02	
最高		31.0	23.4	6.9	8.26	17.8	19.4	45	2.8	<0.03	<0.02	
最低		20.0	18.5	0.7	6.45	17.6	18.4	32	2.6	<0.03	<0.02	

令和 3年 7月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	20.0	19.7	0.8	6.90	18.0	19.3	47	2.6	<0.03	<0.02	
2	雨	23.0	19.8	1.0	6.84							
3	雨	24.0	19.5	1.9	6.67							
4	曇	22.0	19.5	7.1	6.48							
5	曇	27.2	19.8	4.3	6.50							
6	曇	26.5	19.8	2.5	6.59							
7	雨	26.2	19.8	1.3	6.73							
8	曇	25.0	19.8	1.0	6.85							
9	晴	27.8	19.8	0.8	6.86							
10	晴	29.6	19.9	0.9	6.93							
11	晴	29.9	20.4	0.9	6.94							
12	晴	29.5	21.0	0.8	7.00							
13	晴	27.5	21.5	0.7	6.97							
14	曇	26.0	21.9	0.7	6.94							
15	曇	25.1	21.8	0.9	6.97	17.4	17.7	34	2.4	<0.03	<0.02	
16	晴	26.5	21.8	1.7	6.94							
17	晴	28.6	21.8	1.4	6.97							
18	晴	29.3	22.1	1.1	7.06							
19	晴	31.0	22.5	0.8	7.13							
20	晴	30.1	23.1	0.8	7.47							
21	晴	29.5	22.9	0.8	7.32							
22	晴	30.3	23.2	0.9	7.36							
23	晴	31.0	23.2	0.9	7.36							
24	晴	30.5	23.1	1.2	7.30							
25	晴	30.0	23.1	1.0	7.22							
26	曇	28.1	23.1	0.9	7.18							
27	晴	29.5	23.2	1.0	7.27							
28	曇	28.5	23.2	1.2	7.23							
29	晴	29.0	23.0	1.2	7.25							
30	晴	29.0	23.0	1.6	7.40							
31	晴	29.5	23.3	0.7	7.11							
平均		27.7	21.6	1.4	7.02	17.7	18.5	40	2.5	<0.03	<0.02	
最高		31.0	23.3	7.1	7.47	18.0	19.3	47	2.6	<0.03	<0.02	
最低		20.0	19.5	0.7	6.48	17.4	17.7	34	2.4	<0.03	<0.02	