

令和 4年 12月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	9.9	14.8	2.6	7.08	8.1	14.1	43	3.6	0.05	<0.02	
2	晴	7.5	14.4	1.0	7.18							
3	晴	10.7	13.6	0.6	7.33							
4	晴	12.1	13.0	0.4	7.27							
5	曇	9.9	12.2	0.3	7.43							
6	晴	10.0	11.7	0.3	7.47							
7	晴	7.6	11.4	0.3	7.51							
8	晴	10.0	11.2	0.3	7.54							
9	晴	9.9	11.1	0.3	7.46							
10	晴	14.6	10.8	0.3	7.46							
11	曇	12.9	10.7	0.3	7.46							
12	晴	10.2	10.8	0.3	7.50							
13	曇	9.1	10.7	0.3	7.47							
14	晴	10.0	10.9	0.4	7.47							
15	晴	4.8	10.4	0.3	7.45	17.7	20.3	58	4.6	0.05	<0.02	
16	晴	6.0	10.0	0.3	7.46							
17	曇	6.7	9.7	0.3	7.34							
18	晴	5.8	9.3	0.4	7.48							
19	晴	3.2	8.7	0.3	7.52							
20	晴	3.2	8.1	0.4	7.55							
21	晴	7.1	8.0	0.3	7.58							
22	雨	7.8	7.9	0.3	7.60							
23	晴	2.0	8.1	0.4	7.54							
24	晴	4.3	7.8	0.4	7.46							
25	晴	7.2	8.1	0.4	7.44							
26	晴	4.5	7.7	0.4	7.46							
27	晴	5.1	7.3	0.4	7.47							
28	晴	5.2	7.4	0.4	7.45							
29	晴	8.6	7.7	0.3	7.41							
30	晴	7.2	7.8	0.4	7.44							
31	晴	7.8	7.8	0.3	7.41							
平均		7.8	10.0	0.4	7.44	12.9	17.2	50	4.1	0.04	<0.02	
最高		14.6	14.8	2.6	7.60	17.7	20.3	58	4.6	0.05	<0.02	
最低		2.0	7.3	0.3	7.08	8.1	14.1	43	3.6	0.05	<0.02	

令和 4年 12月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	9.9	14.6	0.9	7.38	15.4	19.9	48	4.1	0.04	<0.02	
2	晴	7.5	14.6	1.4	7.25							
3	晴	10.7	14.2	0.7	7.27							
4	晴	12.1	13.6	0.4	7.28							
5	曇	9.9	13.0	0.3	7.46							
6	晴	10.0	12.5	0.3	7.52							
7	晴	7.6	12.0	0.2	7.55							
8	晴	10.0	11.7	0.2	7.58							
9	晴	9.9	11.5	0.2	7.58							
10	晴	14.6	11.5	0.3	7.62							
11	曇	12.9	11.4	0.2	7.54							
12	晴	10.2	11.1	0.2	7.55							
13	曇	9.1	11.0	0.3	7.54							
14	晴	10.0	10.9	0.3	7.53							
15	晴	4.8	10.6	0.3	7.54	17.8	20.6	65	4.6	0.04	<0.02	
16	晴	6.0	10.3	0.3	7.54							
17	曇	6.7	10.0	0.3	7.48							
18	晴	5.8	9.7	0.3	7.53							
19	晴	3.2	9.2	0.3	7.60							
20	晴	3.2	8.7	0.3	7.61							
21	晴	7.1	8.3	0.3	7.62							
22	雨	7.8	8.4	0.3	7.61							
23	晴	2.0	8.3	0.3	7.62							
24	晴	4.3	8.0	0.3	7.60							
25	晴	7.2	7.9	0.3	7.55							
26	晴	4.5	8.0	0.3	7.51							
27	晴	5.1	7.8	0.3	7.51							
28	晴	5.2	7.6	0.3	7.53							
29	晴	8.6	7.7	0.3	7.48							
30	晴	7.2	7.8	0.3	7.46							
31	晴	7.8	7.9	0.3	7.46							
平均		7.8	10.3	0.4	7.51	16.6	20.2	56	4.4	0.04	<0.02	
最高		14.6	14.6	1.4	7.62	17.8	20.6	65	4.6	0.04	<0.02	
最低		2.0	7.6	0.2	7.25	15.4	19.9	48	4.1	0.04	<0.02	