

令和 5年 1月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考	
			水温 ℃	濁度 度	p H	アルカ リ 度 mg/L	硬度 mg/L	蒸 発 残 留 物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	8.1	7.9	0.4	7.37								
2	晴	8.3	7.8	0.3	7.39								
3	晴	7.1	7.8	0.4	7.41								
4	晴	4.7	7.8	0.4	7.43								
5	晴	3.2	7.7	0.4	7.43	15.4	18.6	76	4.2	0.05	<0.02		
6	晴	3.5	7.5	0.4	7.37								
7	晴	5.3	7.4	0.4	7.42								
8	晴	9.1	7.4	0.4	7.41								
9	晴	9.2	7.4	0.4	7.35								
10	晴	4.8	7.5	0.4	7.39								
11	晴	3.1	7.3	0.4	7.52								
12	晴	8.0	7.2	0.4	7.51								
13	晴	7.2	7.2	0.4	7.48								
14	雨	12.1	7.5	0.5	7.49								
15	曇	10.9	7.9	0.7	7.44								
16	曇	10.0	8.7	0.6	7.48								
17	曇	2.5	8.9	0.6	7.46								
18	曇	7.0	9.0	0.4	7.50								
19	晴	6.0	8.9	0.4	7.53	16.6	20.0	30	4.4	0.06	<0.02		
20	晴	6.0	8.5	0.4	7.53								
21	晴	6.2	8.3	0.4	7.44								
22	晴	4.3	7.8	0.4	7.47								
23	雨	5.1	7.6	0.4	7.48								
24	曇	6.0	7.7	0.4	7.47								
25	晴	-0.3	7.1	0.5	7.51								
26	晴	0.0	6.6	0.4	7.51								
27	曇	2.0	6.8	0.5	7.45								
28	晴	3.0	6.2	0.5	7.45								
29	晴	4.1	5.9	0.5	7.40								
30	晴	4.0	5.8	0.5	7.49								
31	晴	1.9	6.0	0.5	7.49								
平均		5.6	7.5	0.4	7.45	16.0	19.3	53	4.3	0.05	<0.02		
最高		12.1	9.0	0.7	7.53	16.6	20.0	76	4.4	0.06	<0.02		
最低		-0.3	5.8	0.3	7.35	15.4	18.6	30	4.2	0.05	<0.02		

令和 5年 1月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	8.1	8.0	0.3	7.47								
2	晴	8.3	8.1	0.3	7.45								
3	晴	7.1	8.0	0.4	7.43								
4	晴	4.7	7.9	0.5	7.46								
5	晴	3.2	7.7	0.4	7.46	14.6	18.2	67	4.2	0.04	<0.02		
6	晴	3.5	7.8	0.3	7.43								
7	晴	5.3	7.7	0.3	7.43								
8	晴	9.1	7.6	0.3	7.45								
9	晴	9.2	7.6	0.3	7.41								
10	晴	4.8	7.7	0.3	7.42								
11	晴	3.1	7.4	0.4	7.56								
12	晴	8.0	7.3	0.3	7.52								
13	晴	7.2	7.5	0.3	7.55								
14	雨	12.1	7.9	0.3	7.53								
15	曇	10.9	8.1	0.4	7.51								
16	曇	10.0	8.5	0.4	7.50								
17	曇	2.5	8.6	0.5	7.52								
18	曇	7.0	8.7	0.4	7.53								
19	晴	6.0	8.8	0.4	7.55	16.0	19.7	36	4.5	0.05	<0.02		
20	晴	6.0	8.7	0.3	7.57								
21	晴	6.2	8.4	0.4	7.55								
22	晴	4.3	8.0	0.3	7.57								
23	雨	5.1	7.8	0.3	7.55								
24	曇	6.0	7.8	0.3	7.55								
25	晴	-0.3	7.3	0.4	7.54								
26	晴	0.0	6.8	0.4	7.54								
27	曇	2.0	6.7	0.4	7.54								
28	晴	3.0	6.4	0.4	7.53								
29	晴	4.1	6.0	0.4	7.50								
30	晴	4.0	5.8	0.4	7.53								
31	晴	1.9	5.9	0.4	7.53								
平均		5.6	7.6	0.4	7.51	15.3	19.0	52	4.4	0.04	<0.02		
最高		12.1	8.8	0.5	7.57	16.0	19.7	67	4.5	0.05	<0.02		
最低		-0.3	5.8	0.3	7.41	14.6	18.2	36	4.2	0.04	<0.02		