

令和 5年 9月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸 発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	28.9	22.8	0.6	7.31							
2	晴	30.9	22.7	0.5	7.32							
3	晴	30.2	22.9	0.6	7.32							
4	曇	30.3	22.7	0.6	7.30							
5	晴	28.0	23.6	1.0	7.90							
6	曇	26.5	24.2	1.7	7.83							
7	曇	24.1	23.4	1.0	7.54	18.1	17.7	51	2.5	0.03	<0.02	
8	雨	22.0	22.7	1.5	7.18							
9	晴	27.4	21.9	1.1	7.22							
10	曇	27.1	22.1	0.9	7.51							
11	雨	26.0	22.3	0.6	7.55							
12	晴	28.0	22.8	0.8	7.70							
13	晴	28.2	22.8	1.1	7.66							
14	雨	25.1	21.7	1.0	7.15							
15	晴	30.2	22.1	0.6	7.22							
16	晴	32.1	22.3	0.6	7.27							
17	晴	28.9	22.4	0.8	7.27							
18	晴	28.0	22.9	1.0	7.29							
19	晴	28.9	22.9	1.1	7.28							
20	晴	28.0	23.7	1.3	7.66							
21	曇	26.0	23.1	1.2	7.57	18.3	19.5	36	2.6	<0.03	<0.02	
22	曇	24.2	22.3	1.0	7.22							
23	晴	25.4	22.7	0.9	7.24							
24	曇	21.1	22.1	1.7	7.05							
25	晴	25.6	21.8	0.9	7.20							
26	晴	25.0	22.0	0.6	7.35							
27	晴	26.5	21.3	0.7	7.17							
28	晴	28.1	21.4	0.6	7.34							
29	晴	26.0	21.5	0.6	7.36							
30	晴	28.1	21.9	0.7	7.39							
平均		27.2	22.5	0.9	7.38	18.2	18.6	44	2.6	<0.03	<0.02	
最高		32.1	24.2	1.7	7.90	18.3	19.5	51	2.6	0.03	<0.02	
最低		21.1	21.3	0.5	7.05	18.1	17.7	36	2.5	<0.03	<0.02	

令和 5年 9月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	28.9	24.0	0.5	7.58							
2	晴	30.9	24.1	0.5	7.47							
3	晴	30.2	24.3	0.5	7.51							
4	曇	30.3	24.3	0.6	7.55							
5	晴	28.0	24.3	0.6	7.58							
6	曇	26.5	24.4	0.9	7.48							
7	曇	24.1	24.0	1.0	7.36	18.7	18.4	54	2.4	<0.03	<0.02	
8	雨	22.0	23.8	0.7	7.38							
9	晴	27.4	23.3	1.1	7.28							
10	曇	27.1	22.9	0.8	7.29							
11	雨	26.0	23.0	0.6	7.37							
12	晴	28.0	23.1	0.5	7.41							
13	晴	28.2	23.2	0.6	7.42							
14	雨	25.1	23.2	0.7	7.39							
15	晴	30.2	23.2	0.6	7.35							
16	晴	32.1	23.5	0.4	7.45							
17	晴	28.9	23.7	0.5	7.47							
18	晴	28.0	23.8	0.7	7.47							
19	晴	28.9	23.9	0.7	7.47							
20	晴	28.0	23.9	0.9	7.40							
21	曇	26.0	23.9	1.0	7.39	18.8	20.0	36	2.6	<0.03	<0.02	
22	曇	24.2	23.8	0.8	7.42							
23	晴	25.4	23.3	0.8	7.31							
24	曇	21.1	23.2	0.9	7.30							
25	晴	25.6	22.7	1.0	7.17							
26	晴	25.0	22.5	0.6	7.27							
27	晴	26.5	22.5	0.5	7.33							
28	晴	28.1	22.5	0.4	7.39							
29	晴	26.0	22.4	0.4	7.43							
30	晴	28.1	22.5	0.5	7.44							
平均		27.2	23.4	0.7	7.40	18.8	19.2	45	2.5	<0.03	<0.02	
最高		32.1	24.4	1.1	7.58	18.8	20.0	54	2.6	<0.03	<0.02	
最低		21.1	22.4	0.4	7.17	18.7	18.4	36	2.4	<0.03	<0.02	