

令和 5年 10月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考	
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	曇	25.9	22.0	0.7	7.44								
2	晴	23.3	22.0	0.7	7.36								
3	晴	23.4	21.4	0.7	7.48								
4	雨	18.5	21.0	1.6	7.40								
5	曇	20.2	21.1	0.8	7.33	15.8	16.7	54.0	3.0	<0.03	<0.02		
6	晴	19.8	20.6	0.7	7.24								
7	晴	19.5	19.6	0.9	7.22								
8	曇	18.4	19.2	0.7	7.25								
9	雨	18.5	18.9	0.6	7.36								
10	晴	19.3	18.2	0.5	7.36								
11	曇	19.0	18.1	0.5	7.40								
12	晴	21.9	18.0	1.0	7.37								
13	晴	21.0	18.5	0.8	7.25								
14	晴	19.5	18.1	0.5	7.34								
15	雨	17.6	18.0	0.5	7.41								
16	晴	19.5	17.9	0.5	7.42								
17	晴	20.2	17.8	0.5	7.40								
18	晴	20.0	17.7	0.5	7.51								
19	晴	20.5	17.5	0.5	7.46	19.4	20.5	53.0	4.3	<0.03	<0.02		
20	晴	22.2	17.3	0.5	7.45								
21	晴	18.4	17.3	0.4	7.43								
22	晴	15.4	17.2	0.4	7.49								
23	晴	16.7	16.8	0.4	7.55								
24	晴	20.0	16.7	0.4	7.51								
25	曇	16.0	16.3	0.4	7.43								
26	晴	19.1	16.1	0.4	7.42								
27	晴	18.6	16.0	0.4	7.45								
28	晴	18.2	16.1	0.4	7.45								
29	晴	17.2	16.0	0.4	7.42								
30	晴	19.0	15.9	0.4	7.45								
31	晴	19.1	15.9	0.4	7.63								
平均		19.5	18.2	0.6	7.41	17.6	18.6	54	3.6	<0.03	<0.02		
最高		25.9	22.0	1.6	7.63	19.4	20.5	54	4.3	<0.03	<0.02		
最低		15.4	15.9	0.4	7.22	15.8	16.7	53	3.0	<0.03	<0.02		

令和 5年 10月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	曇	25.9	22.7	0.5	7.47								
2	晴	23.3	22.4	0.5	7.46								
3	晴	23.4	22.2	0.6	7.42								
4	雨	18.5	22.1	0.6	7.45								
5	曇	20.2	21.7	0.7	7.40	16.2	18.1	58.0	3.0	<0.03	<0.02		
6	晴	19.8	21.2	0.6	7.37								
7	晴	19.5	20.5	0.7	7.36								
8	曇	18.4	20.1	0.7	7.28								
9	雨	18.5	19.6	0.6	7.33								
10	晴	19.3	19.3	0.4	7.40								
11	曇	19.0	18.9	0.4	7.45								
12	晴	21.9	18.8	0.4	7.48								
13	晴	21.0	18.8	0.8	7.40								
14	晴	19.5	18.9	0.5	7.37								
15	雨	17.6	18.7	0.4	7.43								
16	晴	19.5	18.4	0.4	7.51								
17	晴	20.2	18.4	0.4	7.51								
18	晴	20.0	18.3	0.3	7.57								
19	晴	20.5	18.3	0.3	7.54	20.0	21.1	51.0	4.3	<0.03	<0.02		
20	晴	22.2	18.3	0.4	7.48								
21	晴	18.4	18.0	0.4	7.52								
22	晴	15.4	17.5	0.3	7.58								
23	晴	16.7	17.4	0.3	7.60								
24	晴	20.0	17.3	0.3	7.63								
25	曇	16.0	17.2	0.3	7.54								
26	晴	19.1	16.9	0.3	7.56								
27	晴	18.6	16.8	0.3	7.57								
28	晴	18.2	16.6	0.3	7.57								
29	晴	17.2	16.4	0.3	7.56								
30	晴	19.0	16.3	0.3	7.57								
31	晴	19.1	16.4	0.3	7.52								
平均		19.5	18.9	0.4	7.48	18.1	19.6	54	3.6	<0.03	<0.02		
最高		25.9	22.7	0.8	7.63	20.0	21.1	58	4.3	<0.03	<0.02		
最低		15.4	16.3	0.3	7.28	16.2	18.1	51	3.0	<0.03	<0.02		