

令和 5年 11月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	16.0	15.7	0.4	7.41							
2	晴	18.7	15.8	0.4	7.44	20.0	22.2	52	4.5	0.03	<0.02	
3	晴	20.3	15.7	0.4	7.42							
4	晴	21.9	16.0	0.4	7.43							
5	晴	20.3	16.1	0.4	7.41							
6	曇	20.0	16.3	0.4	7.36							
7	曇	18.1	16.6	0.4	7.33							
8	晴	19.6	17.3	2.9	7.42							
9	晴	15.8	17.1	2.7	7.18							
10	雨	16.3	17.3	1.5	7.10							
11	曇	11.9	16.8	0.9	7.17							
12	曇	12.9	16.5	0.6	7.19							
13	晴	9.8	16.1	1.4	7.33							
14	晴	11.0	15.9	0.7	7.34							
15	曇	10.0	14.9	0.4	7.40							
16	晴	14.0	13.7	0.6	7.45	18.7	20.3	47	4.0	<0.03	<0.02	
17	雨	12.9	13.2	0.4	7.44							
18	晴	11.6	12.8	0.7	7.46							
19	晴	13.0	12.4	0.9	7.43							
20	晴	12.9	12.5	0.7	7.42							
21	曇	9.8	12.2	0.6	7.40							
22	晴	14.2	12.0	0.5	7.43							
23	晴	14.9	12.1	0.4	7.42							
24	晴	14.1	12.1	0.4	7.48							
25	晴	10.9	12.1	0.5	7.52							
26	晴	13.1	12.0	0.5	7.42							
27	晴	12.2	12.1	0.5	7.49							
28	晴	13.9	12.0	0.6	7.49							
29	晴	10.5	12.0	0.7	7.46							
30	曇	10.0	12.0	0.7	7.47							
平均		14.4	14.3	0.8	7.39	19.4	21.2	50	4.2	<0.03	<0.02	
最高		21.9	17.3	2.9	7.52	20.0	22.2	52	4.5	0.03	<0.02	
最低		9.8	12.0	0.4	7.10	18.7	20.3	47	4.0	<0.03	<0.02	

令和 5年 11月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	16.0	16.3	0.3	7.52							
2	晴	18.7	16.2	0.3	7.54	19.4	21.6	43	4.8	<0.03	<0.02	
3	晴	20.3	16.3	0.3	7.48							
4	晴	21.9	16.4	0.4	7.49							
5	晴	20.3	16.6	0.3	7.48							
6	曇	20.0	16.8	0.3	7.49							
7	曇	18.1	17.3	0.3	7.45							
8	晴	19.6	17.1	0.3	7.24							
9	晴	15.8	17.3	1.5	7.07							
10	雨	16.3	17.4	1.7	7.19							
11	曇	11.9	17.2	1.1	7.14							
12	曇	12.9	16.7	0.5	7.24							
13	晴	9.8	16.3	0.5	7.23							
14	晴	11.0	15.8	0.7	7.37							
15	曇	10.0	15.6	0.5	7.36							
16	晴	14.0	14.7	0.7	7.46	16.9	19.2	42	3.6	<0.03	<0.02	
17	雨	12.9	14.2	0.5	7.51							
18	晴	11.6	13.5	0.5	7.53							
19	晴	13.0	12.7	0.9	7.49							
20	晴	12.9	12.7	0.9	7.53							
21	曇	9.8	12.6	0.6	7.49							
22	晴	14.2	12.5	0.5	7.47							
23	晴	14.9	12.6	0.4	7.47							
24	晴	14.1	12.6	0.4	7.52							
25	晴	10.9	12.3	0.3	7.59							
26	晴	13.1	12.3	0.4	7.62							
27	晴	12.2	12.3	0.4	7.58							
28	晴	13.9	12.5	0.4	7.56							
29	晴	10.5	12.3	0.5	7.50							
30	曇	10.0	12.1	0.6	7.43							
平均		14.4	14.7	0.6	7.43	18.2	20.4	42	4.2	<0.03	<0.02	
最高		21.9	17.4	1.7	7.62	19.4	21.6	43	4.8	<0.03	<0.02	
最低		9.8	12.1	0.3	7.07	16.9	19.2	42	3.6	<0.03	<0.02	