

令和 8年 9月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	28.2	22.6	0.9	7.70							
2	晴	28.5	23.5	0.8	8.22							
3	曇	28.0	23.6	0.8	8.31	31.0	38.4	111	4.9	0.07	<0.02	
4	雨	23.0	23.1	0.8	7.84							
5	曇	21.0	23.3	0.9	7.72							
6	曇	23.5	23.6	0.9	8.18							
7	雨	22.4	23.2	0.8	7.93							
8	曇	25.5	22.8	0.6	7.66							
9	曇	26.5	22.9	19.8	7.28							
10	雨	21.9	20.6	2.8	7.04							
11	雨	21.9	20.7	2.0	7.20							
12	曇	23.9	20.2	2.1	7.00							
13	雨	23.0	20.4	1.3	7.06							
14	晴	27.2	20.7	1.9	7.07							
15	雨	22.0	20.5	0.7	7.22							
16	雨	22.5	20.6	0.6	7.41							
17	曇	24.0	20.5	0.6	7.41	16.2	16.9	44	2.4	0.06	<0.02	
18	晴	24.9	20.9	0.8	7.43							
19	晴	24.5	21.3	0.6	7.48							
20	曇	25.5	21.7	0.6	7.92							
21	曇	23.0	21.2	0.4	7.65							
22	晴	25.0	21.3	0.4	7.50							
23	曇	24.0	21.9	0.8	7.97							
24	晴	26.0	21.6	0.6	8.07							
25	曇	26.5	22.4	0.5	8.42							
26	曇	24.0	22.1	0.4	8.53							
27	曇	21.0	21.5	0.4	7.47							
28	曇	24.9	21.6	0.4	7.66							
29	曇	20.3	21.2	0.5	7.50							
30	曇	20.0	20.8	0.9	7.35							
平均		24.1	21.7	1.5	7.64	23.6	27.6	78	3.6	0.06	<0.02	
最高		28.5	23.6	19.8	8.53	31.0	38.4	111	4.9	0.07	<0.02	
最低		20.0	20.2	0.4	7.00	16.2	16.9	44	2.4	0.06	<0.02	

令和 8年 9月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	28.2	23.8	0.6	7.72							
2	晴	28.5	23.9	0.6	7.67							
3	曇	28.0	23.7	0.6	7.63	32.2	37.0	106	4.3	0.06	<0.02	
4	雨	23.0	23.7	0.6	7.67							
5	曇	21.0	23.8	0.7	7.66							
6	曇	23.5	23.6	0.7	7.60							
7	雨	22.4	23.0	0.7	7.71							
8	曇	25.5	23.2	0.6	7.62							
9	曇	26.5	23.5	0.9	7.71							
10	雨	21.9	22.6	1.3	7.01							
11	雨	21.9	21.5	1.6	7.20							
12	曇	23.9	21.4	1.4	7.21							
13	雨	23.0	21.6	1.2	7.12							
14	晴	27.2	21.3	0.8	7.29							
15	雨	22.0	21.5	1.0	7.19							
16	雨	22.5	21.1	0.7	7.20							
17	曇	24.0	21.0	0.6	7.28	14.7	15.7	40	2.5	0.07	<0.02	
18	晴	24.9	21.2	0.7	7.32							
19	晴	24.5	21.3	0.8	7.18							
20	曇	25.5	21.5	0.5	7.26							
21	曇	23.0	21.7	0.4	7.36							
22	晴	25.0	21.6	0.4	7.36							
23	曇	24.0	21.9	0.6	7.37							
24	晴	26.0	21.8	0.7	7.56							
25	曇	26.5	22.2	0.5	7.64							
26	曇	24.0	22.4	0.4	7.54							
27	曇	21.0	22.2	0.4	7.46							
28	曇	24.9	21.9	0.4	7.47							
29	曇	20.3	21.7	0.4	7.41							
30	曇	20.0	21.3	0.6	7.43							
平均		24.1	22.2	0.7	7.43	23.4	26.4	73	3.4	0.06	<0.02	
最高		28.5	23.9	1.6	7.72	32.2	37.0	106	4.3	0.07	<0.02	
最低		20.0	21.0	0.4	7.01	14.7	15.7	40	2.5	0.06	<0.02	