

令和2年10月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (滝戸沈砂池 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	全硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	20.2	14.4	0.5	7.54							
2	晴	25.8	14.4	0.8	7.51							
3	晴	27.5	14.2	0.5	7.58							
4	曇	22.3	14.5	0.6	7.54							
5	曇	21.2	14.5	0.5	7.59							
6	晴	24.7	14.3	3.4	7.60							
7	晴	26.0	14.0	0.5	7.61							
8	雨	16.2	14.1	0.7	7.54	41.0	45.0	118	5.6	0.08	<0.02	
9	雨	15.8	14.0	0.9	7.62							
10	雨	17.3	14.4	2.4	7.51							
11	晴	26.8	14.5	1.2	7.62							
12	晴	25.3	14.4	0.7	7.59							
13	晴	27.2	14.5	0.6	7.65							
14	曇	22.7	14.6	0.5	7.47							
15	晴	22.0	14.2	0.6	7.60							
16	曇	18.0	14.0	0.4	7.55							
17	雨	13.3	13.7	0.6	7.55							
18	晴	21.0	13.5	0.5	7.67							
19	曇	14.8	13.0	0.4	7.65	42.0	45.0	112	5.1	0.05	<0.02	
20	晴	17.0	13.1	0.3	7.53							
21	晴	21.6	13.2	0.4	7.53							
22	曇	17.0	13.0	0.4	7.63							
23	雨	18.0	14.0	0.3	7.54							
24	晴	19.7	13.8	0.5	7.56							
25	晴	19.0	13.0	0.4	7.67							
26	晴	16.5	13.0	0.3	7.64							
27	晴	20.0	13.2	0.4	7.64							
28	晴	21.8	13.2	0.5	7.63							
29	晴	23.1	13.2	0.4	7.62							
30	晴	20.8	13.2	0.4	7.71							
31	晴	19.0	12.5	0.4	7.64							
平均		20.7	13.8	0.7	7.59	41.5	45.0	115	5.4	0.07	<0.02	
最高		27.5	14.6	3.4	7.71	42.0	45.0	118	5.6	0.08	<0.02	
最低		13.3	12.5	0.3	7.47	41.0	45.0	112	5.1	0.05	<0.02	