

令和3年5月分

富士川工業用水道 水質試験結果報告書（滝戸沈砂池）

採水時間 9:00

日	天候	気温 °C	水質試験結果（滝戸沈砂池：原水）									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	21.0	13.2	1.1	7.54							
2	晴	19.3	13.3	1.7	7.56							
3	晴	19.0	12.5	1.1	7.62							
4	晴	20.5	12.7	1.0	7.60							
5	晴	20.8	13.2	0.9	7.55							
6	晴	19.8	13.8	0.9	7.61							
7	曇	20.3	13.8	0.7	7.49							
8	晴	21.5	13.7	0.8	7.49							
9	晴	26.0	14.0	0.8	7.58							
10	晴	20.2	13.2	0.9	7.58							
11	曇	19.0	13.8	0.8	7.54							
12	晴	21.7	13.7	0.8	7.53	41.9	43.2	125	10.3	0.06	<0.02	
13	雨	15.7	13.4	0.8	7.48							
14	晴	22.4	14.0	0.8	7.56							
15	晴	26.2	14.2	0.7	7.61							
16	雨	19.0	14.3	0.7	7.51							
17	雨	21.6	14.4	1.2	7.55							
18	曇	22.4	14.3	0.5	7.59							
19	雨	20.2	14.8	0.9	7.55	41.5	38.0	128	9.5	0.01	<0.02	
20	曇	21.7	14.4	0.9	7.56							
21	雨	21.8	15.0	3.5	7.54							
22	曇	19.6	14.6	2.4	7.62							
23	曇	22.8	14.0	0.8	7.64							
24	曇	24.5	14.2	0.9	7.64							
25	晴	22.8	14.1	0.8	7.58							
26	曇	21.7	13.9	0.7	7.61							
27	雨	15.8	13.8	0.8	7.58							
28	曇	21.4	13.8	1.2	7.62							
29	晴	24.0	14.1	0.8	7.58							
30	晴	23.8	14.0	0.7	7.59							
31	晴	25.0	14.3	0.6	7.58							
平均		21.3	13.9	1.0	7.57	41.7	40.6	127	9.9	0.04	<0.02	
最高		26.2	15.0	3.5	7.64	41.9	43.2	128	10.3	0.06	<0.02	
最低		15.7	12.5	0.5	7.48	41.5	38.0	125	9.5	0.01	<0.02	