

令和3年7月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考	
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l		
1	雨	21.0	15.5	6.7	7.50								
2	雨	20.7	16.0	8.1	7.50								
3	雨	22.8	18.3	25.7	7.37								
4	曇	21.6	16.1	5.9	7.50								
5	曇	24.7	15.3	3.7	7.51	39.9	44.4	135	4.7	0.53	<0.02		
6	曇	27.6	15.7	3.5	7.51								
7	曇	25.0	15.0	1.9	7.53								
8	曇	25.3	15.2	0.9	7.54								
9	雨	26.2	16.1	2.6	7.53								
10	晴	30.8	15.4	1.2	7.60								
11	晴	28.4	15.5	0.7	7.59								
12	晴	28.1	15.2	1.1	7.60								
13	晴	28.1	15.6	0.8	7.58								
14	曇	25.9	15.2	1.0	7.50	39.8	41.7	118	5.9	0.09	<0.02		
15	雨	22.8	15.5	2.4	7.50								
16	晴	28.8	15.2	1.3	7.56								
17	晴	29.5	15.0	1.0	7.57								
18	晴	31.2	15.3	0.9	7.58								
19	晴	30.4	15.5	1.0	7.57								
20	晴	29.8	15.5	0.7	7.52								
21	晴	31.0	15.4	0.8	7.54								
22	晴	31.8	15.4	0.7	7.52								
23	晴	30.2	15.5	0.8	7.59								
24	晴	30.4	15.8	0.7	7.59								
25	晴	31.4	15.4	0.6	7.59								
26	晴	31.4	15.4	0.6	7.59								
27	雨												断水作業の為記録なし
28	曇												断水作業の為記録なし
29	晴	28.7	16.2	1.0	7.59								
30	曇	26.4	15.8	3.1	7.53								
31	晴	28.9	17.0	0.8	7.55								
平均		27.5	15.7	2.8	7.54	39.9	43.1	127	5.3	0.31	<0.02		