

令和3年8月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	32.0	15.8	0.8	7.57							
2	晴	32.5	15.7	0.9	7.55							
3	晴	29.4	15.9	0.8	7.58	42.1	43.0	126	6.5	0.06	<0.02	
4	晴	32.4	15.8	0.9	7.55							
5	晴	32.1	16.1	1.7	7.55							
6	晴	31.2	15.7	0.8	7.46							
7	曇	29.8	15.8	0.9	7.54							
8	雨	26.0	16.0	1.3	7.56							
9	雨	28.5	16.3	1.4	7.50							
10	晴	33.5	16.2	2.0	7.59							
11	晴	30.2	15.9	0.9	7.60							
12	曇	28.4	16.0	1.3	7.49							
13	雨	23.8	15.6	1.0	7.48							
14	雨	25.0	18.7	65.4	7.42							
15	雨	27.0	18.8	15.0	7.53							
16	雨	22.9	16.4	10.1	7.55							
17	雨	22.3	15.5	5.3	7.52							
18	雨	28.0	19.3	112.1	7.40	25.0	31.7	199	2.1	6.16	<0.02	
19	曇	27.0	17.0	17.5	7.51							
20	曇	31.0	16.0	9.2	7.64							
21	曇	24.6	15.8	3.2	7.61							
22	曇	29.0	16.0	3.0	7.64							
23	雨	27.9	16.0	3.6	7.64							
24	晴	29.8	15.8	2.0	7.63							
25	晴	28.0	16.2	2.4	7.63							
26	晴	32.5	15.2	1.8	7.58							
27	晴	34.3	16.0	3.3	7.57							
28	晴	31.8	15.2	1.5	7.56							
29	晴	30.5	15.3	1.8	7.60							
30	曇	32.0	15.5	1.1	7.68							
31	晴	30.7	16.5	1.0	7.51							
平均		29.2	16.2	8.8	7.56	33.6	37.4	163	4.3	3.11	<0.02	
最高		34.3	19.3	112.1	7.68	42.1	43.0	199	6.5	6.16	<0.02	
最低		22.3	15.2	0.8	7.40	25.0	31.7	126	2.1	0.06	<0.02	