

令和3年11月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	22.0	13.3	0.4	7.60							
2	晴	20.0	13.2	0.5	7.58	43.2	45.9	129	8.6	0.03	<0.02	
3	晴	19.8	13.2	0.3	7.55							
4	晴	20.5	13.2	0.4	7.53							
5	晴	20.5	13.0	0.4	7.57							
6	晴	18.0	13.0	0.4	7.55							
7	曇	15.5	13.2	0.3	7.53							
8	晴	24.3	13.3	0.7	7.63							
9	雨	15.5	13.5	0.6	7.59							
10	晴	18.7	13.8	0.5	7.60							
11	晴	18.8	12.3	0.5	7.59							
12	晴	20.2	12.2	0.4	7.65							
13	晴	18.6	12.0	0.2	7.64							
14	晴	15.0	12.1	0.8	7.57							
15	晴	16.5	12.1	0.5	7.56							
16	晴	18.0	12.2	0.4	7.64							
17	晴	19.0	13.0	0.3	7.64							
18	晴	17.2	12.9	0.4	7.55							
19	晴	15.5	12.2	0.4	7.64							
20	晴	20.5	12.0	0.3	7.64							
21	曇	13.0	12.3	0.5	7.57							
22	晴	18.0	13.0	0.4	7.58							
23	晴	15.5	13.2	0.6	7.54							
24	晴	16.0	11.8	0.4	7.64	42.4	45.7	110	7.5	0.03	<0.02	
25	晴	10.0	11.8	0.5	7.58							
26	晴	17.5	11.8	0.4	7.56							
27	晴	15.0	11.7	0.3	7.57							
28	晴	15.0	11.2	0.3	7.62							
29	晴	9.0	11.2	0.2	7.54							
30	晴	14.0	11.4	0.3	7.68							
31												
平均		17.2	12.5	0.4	7.59	42.8	45.8	120	8.1	0.03	<0.02	
最高		24.3	13.8	0.8	7.68	43.2	45.9	129	8.6	0.03	<0.02	
最低		9.0	11.2	0.2	7.53	42.4	45.7	110	7.5	0.03	<0.02	