

様式一工水2 (A4用紙)

令和4年2月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	8.0	10.3	0.2	7.57	41.5	43.9	122	9.7	0.02	<0.02	
2	晴	8.8	10.3	0.4	7.57							
3	曇	5.5	10.0	0.3	7.58							
4	曇	7.7	10.4	0.3	7.61							
5	晴	7.5	10.3	0.3	7.60							
6	晴	5.9	10.0	0.2	7.60							
7	晴	9.2	10.0	0.2	7.70							
8	曇	5.7	10.4	0.4	7.57							
9	晴	8.1	10.8	0.2	7.54							
10	雨	4.5	11.0	0.3	7.54							
11	晴	9.0	10.5	0.2	7.63							
12	晴	10.4	10.4	0.4	7.61							
13	曇	6.1	10.6	0.2	7.54							
14	曇	6.2	11.1	0.3	7.54							
15	晴	9.5	11.0	0.3	7.63	40.8	44.7	116	10.7	0.02	<0.02	
16	晴	11.6	10.6	0.4	7.51							
17	晴	9.0	10.2	0.3	7.58							
18	晴	9.3	10.0	0.3	7.62							
19	曇	9.0	10.5	0.2	7.63							
20	曇	10.2	11.2	1.6	7.73							
21	晴	7.1	10.0	0.6	7.60							
22	晴	8.0	9.5	0.5	7.78							
23	晴	10.5	9.6	0.8	7.73							
24	晴	6.2	10.0	0.4	7.78							
25	晴	8.2	10.0	0.6	7.80							
26	晴	13.0	10.0	0.4	7.81							
27	晴	15.0	10.6	0.5	7.69							
28	晴	10.6	10.5	0.6	7.60							
29												
30												
31												
平均		8.6	10.4	0.4	7.63	41.2	44.3	119	10.2	0.02	<0.02	
最高		15.0	11.2	1.6	7.81	41.5	44.7	122	10.7	0.02	<0.02	
最低		4.5	9.5	0.2	7.51	40.8	43.9	116	9.7	0.02	<0.02	