

令和4年6月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	25.8	14.6	1.7	7.63							
2	晴	25.3	14.0	1.3	7.71							
3	晴	24.5	14.2	1.3	7.72							
4	晴	21.8	14.6	0.8	7.61							
5	晴	23.3	14.4	1.7	7.59							
6	雨	17.2	14.6	3.6	7.51							
7	晴	22.5	14.0	1.1	7.64	40.5	46.3	121	8.3	0.05	<0.02	
8	晴	19.5	14.2	1.1	7.60							
9	晴	22.0	14.2	1.6	7.56							
10	晴	21.8	14.3	1.5	7.58							
11	曇	23.5	14.5	2.0	7.66							
12	晴	21.6	14.5	1.2	7.60							
13	晴	22.8	14.2	1.2	7.58							
14	雨	19.3	14.3	1.0	7.55							
15	雨	17.8	14.2	0.6	7.62							
16	曇	20.1	14.5	0.5	7.59							
17	晴	22.5	14.7	0.7	7.61							
18	曇	22.5	14.6	0.8	7.60							
19	晴	25.0	14.5	0.9	7.67							
20	晴	24.8	15.0	0.9	7.59							
21	晴	27.0	15.2	0.7	7.59	41.9	44.3	118	8.3	0.02	<0.02	
22	曇	24.7	15.6	2.2	7.58							
23	雨	22.5	15.0	0.9	7.64							
24	曇	24.8	15.0	1.0	7.58							
25	晴	30.8	15.8	0.9	7.64							
26	晴	27.0	15.5	0.8	7.60							
27	晴	25.5	15.5	0.9	7.73							
28	晴	30.0	15.7	0.8	7.58							
29	晴	26.7	16.0	1.1	7.50							
30	晴	28.7	15.7	1.2	7.59							
31												
平均		23.7	14.8	1.2	7.61	41.2	45.3	120	8.3	0.04	<0.02	
最高		30.8	16.0	3.6	7.73	41.9	46.3	121	8.3	0.05	<0.02	
最低		17.2	14.0	0.5	7.50	40.5	44.3	118	8.3	0.02	<0.02	