

令和4年10月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	27.0	15.2	1.1	7.66							
2	曇	24.5	15.0	1.4	7.60							
3	晴	27.8	15.0	1.9	7.59							
4	晴	27.6	15.3	0.9	7.64	43.6	42.5	128	6.0	0.21	<0.02	
5	晴	30.5	15.3	1.8	7.57							
6	晴	32.0	15.0	0.8	7.54							
7	雨	24.5	14.4	3.2	7.57							
8	曇	21.7	14.8	1.9	7.61							
9	曇	26.5	14.3	2.2	7.60							
10	晴	28.6	15.0	2.9	7.56							
11	晴	28.0	15.0	2.0	7.65							
12	晴	27.8	14.7	1.3	7.61							
13	晴	29.0	14.8	1.1	7.54							
14	晴	31.7	14.8	1.0	7.64							
15	晴	26.0	15.0	1.7	7.70							
16	晴	28.3	15.2	0.8	7.67							
17	曇	29.0	14.9	1.1	7.58							
18	雨	25.0	15.0	1.1	7.61							
19	雨	26.0	14.5	0.8	7.63	44.5	44.8	126	6.7	0.08	<0.02	
20	雨	25.5	13.2	0.8	7.67							
21	曇	20.0	13.4	0.7	7.64							
22	曇	23.7	14.0	4.3	7.61							
23	雨	20.5	14.1	1.3	7.66							
24	雨	22.5	14.2	1.0	7.56							
25	曇	23.0	13.8	1.0	7.58							
26	晴	21.3	13.0	1.0	7.70							
27	晴	28.0	12.8	0.7	7.68							
28	晴	25.0	13.0	0.6	7.59							
29	曇	21.5	13.7	1.2	7.69							
30	晴	25.4	13.4	0.6	7.67							
31	晴	19.5	13.6	0.8	7.69							
平均		25.7	14.4	1.4	7.62	44.1	43.7	127	6.4	0.15	<0.02	
最高		32.0	15.3	4.3	7.70	44.5	44.8	128	6.7	0.21	<0.02	
最低		19.5	12.8	0.6	7.54	43.6	42.5	126	6.0	0.08	<0.02	