

令和5年3月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	11.8	11.2	0.5	7.66							
2	晴	15.3	12.4	1.2	7.69							
3	曇	10.8	12.0	0.5	7.68							
4	晴	10.1	11.2	0.9	7.67							
5	曇	12.5	11.8	0.6	7.76							
6	晴	13.5	12.0	0.7	7.69							
7	晴	15.2	12.2	0.8	7.68	42.9	43.8	128	10.3	0.04	<0.02	
8	晴	16.5	11.7	0.6	7.72							
9	晴	17.2	12.0	0.6	7.74							
10	曇	13.6	12.7	1.0	7.62							
11	晴	17.8	12.2	0.7	7.67							
12	曇	12.3	12.1	0.6	7.59							
13	雨	13.0	13.0	0.7	7.58							
14	曇	13.0	12.3	0.9	7.64							
15	晴	14.7	12.1	1.2	7.66							
16	晴	15.7	12.3	0.8	7.63							
17	晴	18.5	12.8	0.8	7.68							
18	雨	11.4	12.8	1.8	7.56							
19	晴	11.0	12.0	0.7	7.66							
20	晴	14.7	12.0	0.9	7.66							
21	曇	15.2	12.0	0.5	7.68	41.8	41.4	134	10.4	0.03	<0.02	
22	晴	21.0	13.0	0.8	7.72							
23	雨	14.7	12.8	0.6	7.61							
24	曇	18.4	13.9	1.9	7.63							
25	雨	13.2	13.3	2.2	7.60							
26	雨	12.0	12.7	1.3	7.59							
27	曇	11.5	12.6	1.3	7.59							
28	曇	12.1	12.1	0.9	7.62							
29	晴	16.2	12.2	0.8	7.64							
30	晴	16.5	12.0	1.1	7.71							
31	晴	14.0	12.0	1.0	7.65							
平均		14.3	12.3	0.9	7.65	42.4	42.6	131	10.4	0.04	<0.02	
最高		21.0	13.9	2.2	7.76	42.9	43.8	134	10.4	0.04	<0.02	
最低		10.1	11.2	0.5	7.56	41.8	41.4	128	10.3	0.03	<0.02	