

令和5年6月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	23.0	14.0	0.5	7.62							
2	雨	18.7	15.0	2.8	7.40							
3	曇	18.0	15.8	826.8	7.65							
4	晴	22.5	15.0	9.7	7.57							
5	曇	21.2	14.0	4.0	7.64							
6	曇	20.0	14.0	3.2	7.63							
7	晴	24.0	14.3	1.3	7.71	37.6	39.9	112	5.1	0.10	<0.02	
8	晴	25.3	14.7	1.4	7.65							
9	雨	18.2	15.2	5.2	7.59							
10	曇	25.0	15.0	3.1	7.76							
11	雨	20.0	14.8	2.4	7.54							
12	雨	20.8	14.9	1.3	7.58							
13	晴	27.2	15.0	1.0	7.65							
14	曇	23.5	15.2	1.4	7.57							
15	曇	21.2	14.8	0.7	7.56							
16	晴	22.4	14.7	0.8	7.66							
17	晴	28.2	14.8	0.7	7.65							
18	曇	25.7	15.0	1.6	7.68							
19	曇	26.0	15.0	1.8	7.66							
20	曇	20.8	14.7	0.7	7.63							
21	晴	26.0	14.5	0.8	7.65	40.4	41.1	137	6.1	0.07	<0.02	
22	雨	20.7	14.6	1.0	7.58							
23	曇	24.0	14.6	1.2	7.70							
24	晴	25.4	14.7	0.8	7.67							
25	曇	26.0	14.8	0.6	7.70							
26	曇	23.0	14.9	1.7	7.65							
27	曇	24.0	15.2	0.9	7.50							
28	曇	26.8	15.2	1.1	7.63							
29	曇	28.0	15.2	0.6	7.64							
30	曇	25.5	15.5	0.8	7.48							
31												
平均		23.4	14.8	29.3	7.62	39.0	40.5	125	5.6	0.09	<0.02	
最高		28.2	15.8	826.8	7.76	40.4	41.1	137	6.1	0.10	<0.02	
最低		18.0	14.0	0.5	7.40	37.6	39.9	112	5.1	0.07	<0.02	